



UL Verification Services Inc.
7036 Snowdrift Road
Allentown, PA 18106
610-774-1300



Electrical Test Report

Relavant Standards
ANSI C82.77-2002

Prepared For
H E Williams Inc
831 W Fairview Ave
PO Box 837
Carthage, MO 64836-0837
United States

Catalog Number
SRKA-X4-L52/830-X-XXX-UNV (Driver 6)

Test Number
12118431.10

Test Date

Prepared By

Javier Caban, Technician

Approved By

Jeffrey Lockner, Project Engineer

The results contained in this report pertain only to the tested sample.

This report shall not be reproduced, except in full, without written approval of Underwriters Laboratories.

This report must not be used by the client to claim product certification, approval, or endorsement by
NVLAP, NIST, or any agency of the Federal Government.



UL Verification Services Inc.
7036 Snowdrift Road
Allentown, PA 18106
610-774-1300



Luminaire Description: White formed steel housing, clear plastic optic. Tested in Columbia CS Bi-Pin
2L reference housing.
Catalog Number: SRKA-X4-L52/830-X-XXX-UNV (Driver 6)
Lamp: 112 white LEDs
Mounting: Surface – Ceiling
Ballast/Driver: One Philips XI040C110V054BST1 driver

Luminaire



Test Conditions

Test Temperature: 25.3 °C

Input Electrical Values

Voltage:	120 VAC	277 VAC
Current:	0.3004 A	0.1322 A
Power:	35.90 W	35.40 W
Power Factor:	0.996	0.967
Frequency:	60 Hz	60 Hz
Voltage THD:	0.05%	0.05%
Current THD:	7.00%	12.16%