**IES INDOOR REPORT**
**PHOTOMETRIC FILENAME : 4DR-TL-L10-8TW-DIM-UNV-OW-OF-CS_4000K_.IES**

**DESCRIPTION INFORMATION (From Photometric File)**

IESNA:LM-63-2002
[TEST] GEN from BALLABS TEST NO. 20685.0
[TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC
[ISSUEDATE] 2026-10-14
[MANUFAC] WILLIAMS INDOOR
[OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO
[LUMINAIRE] 4" RND RECESSED LED DOWNLIGHT
[MORE] OPEN SEMI-SPEC SPUN ALUMINUM REFLECTOR (WIDE)
[LUMCAT] 4DR-TL-L10-8TW-DIM-UNV-OW-OF-CS_4000K_
[LAMPCAT] BRIDGELUX V13 BXRE
[_SEARCH_SOURCETYPE] LED
[_SEARCH_APPLICATION] Indoor, Classroom, Commercial, Corridor, Hotel, Industrial, Office, Downlight
[_SEARCH_MOUNTING] Recessed

**CHARACTERISTICS**

| | |
|---|---|
| Lumens Per Lamp | N.A. (absolute) |
| Total Lamp Lumens | N.A. (absolute) |
| Luminaire Lumens | 1054 |
| Total Luminaire Efficiency | N.A. |
| Luminaire Efficacy Rating (LER) | 111 |
| Total Luminaire Watts | 9.5 |
| Ballast Factor | 1.00 |
| CIE Type | Direct |
| Spacing Criterion (0-180) | 1.22 |
| Spacing Criterion (90-270) | 1.22 |
| Spacing Criterion (Diagonal) | 0.94 |
| Basic Luminous Shape | Circular |
| Luminous Length (0-180) | 0.37 ft (Diameter) |
| Luminous Width (90-270) | 0.37 ft (Diameter) |
| Luminous Height | 0.00 ft |

**LUMINANCE DATA (cd/sq.m)**

| Angle In Degrees | Average 0-Deg | Average 45-Deg | Average 90-Deg |
|---|---|---|---|
| 45 | 3196 | 3196 | 3196 |
| 55 | 985 | 985 | 985 |
| 65 | 122 | 122 | 122 |
| 75 | 0 | 0 | 0 |
| 85 | 0 | 0 | 0 |

Photometric Toolbox (R) Copyright 2002-2019 by Lighting Analysts, Inc.
Calculations based on published IES Methods and recommendations, values rounded for display purposes.
Results derived from content of manufacturers photometric file.

**IES INDOOR REPORT**
**PHOTOMETRIC FILENAME : 4DR-TL-L10-8TW-DIM-UNV-OW-OF-CS_4000K_.IES**

**CANDELA TABULATION**

| | 0 |
|---|---|
| **0** | 904.571 |
| **5** | 931.558 |
| **10** | 959.545 |
| **15** | 979.535 |
| **20** | 1023.015 |
| **25** | 1114.971 |
| **30** | 873.586 |
| **35** | 153.427 |
| **40** | 39.981 |
| **45** | 21.990 |
| **50** | 11.495 |
| **55** | 5.497 |
| **60** | 2.499 |
| **65** | 0.500 |
| **70** | 0.500 |
| **75** | 0.000 |
| **80** | 0.000 |
| **85** | 0.000 |
| **90** | 0.000 |

Photometric Toolbox (R) Copyright 2002-2019 by Lighting Analysts, Inc.
Calculations based on published IES Methods and recommendations, values rounded for display purposes.
Results derived from content of manufacturers photometric file.

**IES INDOOR REPORT**
**PHOTOMETRIC FILENAME : 4DR-TL-L10-8TW-DIM-UNV-OW-OF-CS_4000K_.IES**

**ZONAL LUMEN SUMMARY**

| Zone | Lumens | %Lamp | %Fixt |
|---|---|---|---|
| 0-20 | 369.66 | N.A. | 35.10 |
| 0-30 | 845.55 | N.A. | 80.20 |
| 0-40 | 1029.06 | N.A. | 97.60 |
| 0-60 | 1052.84 | N.A. | 99.90 |
| 0-80 | 1053.95 | N.A. | 100.00 |
| 0-90 | 1053.95 | N.A. | 100.00 |
| 10-90 | 964.35 | N.A. | 91.50 |
| 20-40 | 659.39 | N.A. | 62.60 |
| 20-50 | 677.63 | N.A. | 64.30 |
| 40-70 | 24.77 | N.A. | 2.40 |
| 60-80 | 1.11 | N.A. | 0.10 |
| 70-80 | 0.13 | N.A. | 0.00 |
| 80-90 | 0.00 | N.A. | 0.00 |
| 90-110 | 0.00 | N.A. | 0.00 |
| 90-120 | 0.00 | N.A. | 0.00 |
| 90-130 | 0.00 | N.A. | 0.00 |
| 90-150 | 0.00 | N.A. | 0.00 |
| 90-180 | 0.00 | N.A. | 0.00 |
| 110-180 | 0.00 | N.A. | 0.00 |
| 0-180 | 1053.95 | N.A. | 100.00 |

Total Luminaire Efficiency = N.A.%

**ZONAL LUMEN SUMMARY**

| Zone | Lumens |
|---|---|
| 0-10 | 89.60 |
| 10-20 | 280.06 |
| 20-30 | 475.89 |
| 30-40 | 183.50 |
| 40-50 | 18.24 |
| 50-60 | 5.54 |
| 60-70 | 0.98 |
| 70-80 | 0.13 |
| 80-90 | 0.00 |
| 90-100 | 0.00 |
| 100-110 | 0.00 |
| 110-120 | 0.00 |
| 120-130 | 0.00 |
| 130-140 | 0.00 |
| 140-150 | 0.00 |
| 150-160 | 0.00 |
| 160-170 | 0.00 |
| 170-180 | 0.00 |

Photometric Toolbox (R) Copyright 2002-2019 by Lighting Analysts, Inc.
Calculations based on published IES Methods and recommendations, values rounded for display purposes.
Results derived from content of manufacturers photometric file.

**IES INDOOR REPORT**
**PHOTOMETRIC FILENAME : 4DR-TL-L10-8TW-DIM-UNV-OW-OF-CS_4000K_.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

| RC | 80 | | | | 70 | | | | 50 | | | 30 | | | 10 | | | 0 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| RW | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 0 |
| 0 | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 | 106 | 106 | 106 | 102 | 102 | 102 | 100 |
| 1 | 114 | 111 | 109 | 106 | 111 | 109 | 107 | 105 | 105 | 103 | 102 | 101 | 100 | 98 | 98 | 97 | 96 | 94 |
| 2 | 108 | 104 | 100 | 96 | 106 | 102 | 98 | 95 | 99 | 96 | 93 | 96 | 93 | 91 | 93 | 91 | 89 | 88 |
| 3 | 103 | 97 | 92 | 88 | 101 | 95 | 91 | 87 | 93 | 89 | 86 | 90 | 87 | 85 | 88 | 86 | 83 | 82 |
| 4 | 98 | 91 | 85 | 81 | 96 | 90 | 85 | 81 | 87 | 83 | 80 | 85 | 82 | 79 | 84 | 81 | 78 | 77 |
| 5 | 93 | 85 | 79 | 75 | 92 | 84 | 79 | 75 | 82 | 78 | 74 | 81 | 77 | 74 | 79 | 76 | 73 | 72 |
| 6 | 89 | 80 | 74 | 70 | 87 | 79 | 74 | 70 | 78 | 73 | 69 | 76 | 72 | 69 | 75 | 71 | 68 | 67 |
| 7 | 84 | 75 | 69 | 65 | 83 | 75 | 69 | 65 | 73 | 68 | 65 | 72 | 68 | 64 | 71 | 67 | 64 | 63 |
| 8 | 80 | 71 | 65 | 61 | 79 | 70 | 65 | 61 | 69 | 64 | 61 | 68 | 64 | 60 | 67 | 63 | 60 | 59 |
| 9 | 76 | 67 | 61 | 57 | 75 | 66 | 61 | 57 | 66 | 60 | 57 | 65 | 60 | 57 | 64 | 60 | 57 | 55 |
| 10 | 73 | 63 | 58 | 54 | 72 | 63 | 57 | 54 | 62 | 57 | 54 | 61 | 57 | 53 | 61 | 56 | 53 | 52 |

Photometric Toolbox (R) Copyright 2002-2019 by Lighting Analysts, Inc.
Calculations based on published IES Methods and recommendations, values rounded for display purposes.
Results derived from content of manufacturers photometric file.

**IES INDOOR REPORT**
**PHOTOMETRIC FILENAME : 4DR-TL-L10-8TW-DIM-UNV-OW-OF-CS_4000K_.IES**

**UGR TABLE - CORRECTED**


| Reflectances | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Ceiling Cavity | | 70 | 70 | 50 | 50 | 30 | 70 | 70 | 50 | 50 | 30 |
| Walls | | 50 | 30 | 50 | 30 | 30 | 50 | 30 | 50 | 30 | 30 |
| Floor Cavity | | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 |
| Room Size | | UGR Viewed Crosswise | | | | | UGR Viewed Endwise | | | | |
| X=2H | Y=2H | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 |
| | 3H | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 |
| | 4H | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 |
| | 6H | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 |
| | 8H | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 |
| | 12H | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 |
| 4H | 2H | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 |
| | 3H | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 |
| | 4H | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 |
| | 6H | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 |
| | 8H | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 |
| | 12H | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 |
| 8H | 4H | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 |
| | 6H | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 |
| | 8H | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 |
| | 12H | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 |
| 12H | 4H | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 |
| | 6H | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 |
| | 8H | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 |

Maximum UGR = 0.2

Photometric Toolbox (R) Copyright 2002-2019 by Lighting Analysts, Inc.
Calculations based on published IES Methods and recommendations, values rounded for display purposes.
Results derived from content of manufacturers photometric file.

**IES INDOOR REPORT**
**PHOTOMETRIC FILENAME : 4DR-TL-L10-8TW-DIM-UNV-OW-OF-CS_4000K_.IES**

**POLAR GRAPH**




Maximum Candela = 1114.971  Located At Horizontal Angle = 0, Vertical Angle = 25
# 1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)
# 2 - Horizontal Cone Through Vertical Angle (25) (Through Max. Cd.)

Photometric Toolbox (R) Copyright 2002-2019 by Lighting Analysts, Inc.
Calculations based on published IES Methods and recommendations, values rounded for display purposes.
Results derived from content of manufacturers photometric file.