



IES INDOOR REPORT

PHOTOMETRIC FILENAME : 6AR-L10-835-DIM-UNV-AN-OF-WH_0 DEGREE TILT.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
 [TEST]BALLABS TEST NO. 20413.0
 [TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC
 [ISSUE DATE] 23-MAY-2018
 [MANUFAC] WILLIAMS INDOOR
 [OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO
 [LUMINAIRE] GEN7 V13 LED 6"SHORT HEATSINK 6"RND ADJ DOWNLIGHT @ 0 TILT
 [MORE] ACRYC NARROW TIR OPTIC & 6"WHITE TRIM w/ANGLED
 [MORE] SOLITE LENS ADVANCE # XI025C070V054DSM5 @ 530mA
 [LUMCAT] 6AR-L10-835-DIM-UNV-AN-OF-WH_0 DEG TILT
 [LAMPCAT] BXRE-35E2000
 [SEARCH_SOURCETYPE] LED
 [SEARCH_APPLICATION] Indoor, Classroom, Industrial, Office, Direct, Downlight
 [SEARCH_MOUNTING] Recessed

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	907
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	86
Total Luminaire Watts	10.5
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	0.48
Spacing Criterion (90-270)	0.42
Spacing Criterion (Diagonal)	0.44
Basic Luminous Shape	Circular
Luminous Length (0-180)	0.50 ft (Diameter)
Luminous Width (90-270)	0.50 ft (Diameter)
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	1549	1627	1549
55	859	907	907
65	778	778	389
75	635	635	212
85	314	0	0

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 6AR-L10-835-DIM-UNV-AN-OF-WH_0 DEGREE TILT.IES

CANDELA TABULATION

	<u>0.0</u>	<u>22.5</u>	<u>45.0</u>	<u>67.5</u>	<u>90.0</u>	<u>112.5</u>	<u>135.0</u>	<u>157.5</u>	<u>180.0</u>
0	3820.0	3820.0	3820.0	3820.0	3820.0	3820.0	3820.0	3820.0	3820.0
5	3680.5	3738.0	3672.0	3559.0	3422.5	3282.0	3172.5	3061.0	2981.0
10	2870.0	2878.5	2804.5	2585.0	2433.0	2215.5	2098.5	2018.5	1959.5
15	1699.0	1716.5	1612.0	1434.0	1310.0	1188.0	1122.5	1081.5	1064.0
20	814.5	841.5	766.5	649.0	605.0	554.5	529.0	543.5	545.5
25	342.0	355.5	309.0	272.0	245.5	238.0	235.5	260.0	264.5
30	146.5	148.0	132.5	114.5	99.5	105.0	110.5	127.5	138.0
35	63.0	64.0	59.5	53.0	53.0	52.5	57.0	65.5	72.0
40	33.5	35.5	33.5	32.0	33.0	33.0	34.0	36.5	39.0
45	20.0	20.5	21.0	21.0	20.0	20.0	21.5	22.0	23.0
50	14.0	14.0	14.5	14.5	14.0	14.0	15.0	15.0	16.0
55	9.0	9.5	9.5	10.0	9.5	9.0	9.5	10.5	10.5
60	7.0	8.0	7.5	7.5	6.5	6.0	5.5	6.0	6.0
65	6.0	6.5	6.0	5.5	3.0	3.0	2.5	1.5	1.5
70	5.0	5.0	4.0	3.0	1.5	1.0	0.0	0.5	0.0
75	3.0	4.5	3.0	2.0	1.0	0.5	0.0	0.0	0.0
80	2.5	2.0	1.5	1.0	1.0	0.0	0.0	0.5	0.5
85	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

IES INDOOR REPORT**PHOTOMETRIC FILENAME : 6AR-L10-835-DIM-UNV-AN-OF-WH_0 DEGREE TILT.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	684.74	N.A.	75.50
0-30	832.20	N.A.	91.80
0-40	874.47	N.A.	96.40
0-60	900.87	N.A.	99.30
0-80	906.67	N.A.	100.00
0-90	906.95	N.A.	100.00
10-90	611.81	N.A.	67.50
20-40	189.73	N.A.	20.90
20-50	207.10	N.A.	22.80
40-70	30.55	N.A.	3.40
60-80	5.80	N.A.	0.60
70-80	1.65	N.A.	0.20
80-90	0.27	N.A.	0.00
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	906.95	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	295.13
10-20	389.61
20-30	147.45
30-40	42.28
40-50	17.37
50-60	9.03
60-70	4.15
70-80	1.65
80-90	0.27
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 6AR-L10-835-DIM-UNV-AN-OF-WH_0 DEGREE TILT.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC RW	80				70				50			30			10			0
	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	60	60	60	60	58	58	58	58	56	56	56	53	53	53	51	51	51	50
1	57	56	55	54	56	55	54	54	53	53	52	51	51	50	50	49	49	48
2	55	53	52	51	54	53	51	50	51	50	49	50	49	48	48	48	47	46
3	53	51	49	48	53	50	49	47	49	48	46	48	47	46	47	46	45	44
4	52	49	47	45	51	48	46	45	47	46	44	46	45	44	45	44	43	43
5	50	47	45	43	49	46	44	43	46	44	43	45	43	42	44	43	42	41
6	48	45	43	41	48	45	43	41	44	42	41	43	42	41	43	42	40	40
7	47	44	41	40	46	43	41	40	43	41	39	42	41	39	42	40	39	39
8	46	42	40	38	45	42	40	38	41	40	38	41	39	38	41	39	38	37
9	44	41	39	37	44	41	39	37	40	38	37	40	38	37	39	38	37	36
10	43	40	37	36	43	39	37	36	39	37	36	39	37	36	38	37	36	35

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 6AR-L10-835-DIM-UNV-AN-OF-WH_0 DEGREE TILT.IES

UGR TABLE - CORRECTED

Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size UGR Viewed Crosswise


X=2H	Y=2H	4.3	5.2	4.6	5.5	5.8	3.8	4.8	4.2	5.1	5.4
	3H	6.0	6.8	6.4	7.2	7.6	4.2	5.0	4.5	5.3	5.7
	4H	6.7	7.5	7.1	7.8	8.2	4.2	5.0	4.6	5.3	5.7
	6H	7.2	7.9	7.6	8.3	8.7	4.3	4.9	4.7	5.3	5.7
	8H	7.4	8.0	7.8	8.4	8.8	4.3	4.9	4.7	5.3	5.7
	12H	7.4	8.0	7.8	8.4	8.8	4.2	4.8	4.7	5.2	5.6

UGR Viewed Endwise

4H	2H	4.7	5.5	5.1	5.8	6.2	4.0	4.8	4.4	5.1	5.5
	3H	6.7	7.3	7.1	7.7	8.1	4.5	5.1	4.9	5.5	5.9
	4H	7.6	8.2	8.1	8.6	9.1	4.6	5.2	5.1	5.6	6.1
	6H	8.3	8.7	8.8	9.2	9.7	4.7	5.2	5.2	5.7	6.1
	8H	8.4	8.9	8.9	9.3	9.8	4.7	5.2	5.2	5.6	6.1
	12H	8.4	8.8	8.9	9.3	9.8	4.7	5.1	5.2	5.6	6.0
8H	4H	7.7	8.2	8.2	8.6	9.1	4.8	5.2	5.3	5.7	6.2
	6H	8.5	8.8	9.0	9.3	9.8	5.0	5.3	5.5	5.8	6.3
	8H	8.7	8.9	9.2	9.5	10.0	5.0	5.3	5.5	5.8	6.3
	12H	8.7	8.9	9.2	9.4	10.0	4.9	5.2	5.5	5.7	6.3
12H	4H	7.7	8.1	8.2	8.5	9.0	4.8	5.2	5.3	5.6	6.1
	6H	8.4	8.7	9.0	9.2	9.8	5.0	5.3	5.5	5.7	6.3
	8H	8.6	8.9	9.2	9.4	10.0	5.0	5.3	5.5	5.8	6.3

Maximum UGR = 10.0

POLAR GRAPH



Maximum Candela = 3820 Located At Horizontal Angle = 0, Vertical Angle = 0

1 - Vertical Plane Through Horizontal Angles (90 - 270)

2 - Horizontal Cone Through Vertical Angle (0) (Through Max. Cd.)