



IES INDOOR REPORT

PHOTOMETRIC FILENAME : 6DR-TL-L20-835-(L17)-DIM-UNV-OW-OF-CS_.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST]GEN FROM BALLABS TEST NO. 20687.0

[TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC

[ISSUE]DATE 11-04-2020

[MANUFAC] WILLIAMS INDOOR

[OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO

[LUMINAIRE] 1 BRIDGELUX V13 LED 6"RND RECESSED CAST HOUSING DOWNLIGHT

[MORE] OPEN SEMI-SPEC SPUN ALUMINUM REFLECTOR (WIDE)

[LUMCAT] 6DR-TL-L20-835-(L17)-DIM-UNV-OW-OF-CS

[LAMPCAT] V13 BXRE-35E2000

[_SEARCH_SOURCETYPE] LED

[_SEARCH_APPLICATION] Indoor, Architectural, Classroom, Commercial, Healthcare, Office, Downlight

[_SEARCH_MOUNTING] Recessed

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1710
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	105
Total Luminaire Watts	16.3
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	0.98
Basic Luminous Shape	Circular
Luminous Length (0-180)	0.48 ft (Diameter)
Luminous Width (90-270)	0.48 ft (Diameter)
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	3167	3167	3167
55	1103	1103	1103
65	230	230	230
75	0	0	0
85	0	0	0

IES INDOOR REPORT
PHOTOMETRIC FILENAME : 6DR-TL-L20-835-(L17)-DIM-UNV-OW-OF-CS_.IES

CANDELA TABULATION

	<u>0</u>
0	1364.084
5	1288.211
10	1417.929
15	1415.482
20	1478.302
25	1616.994
30	1588.440
35	492.767
40	67.715
45	37.529
50	22.028
55	10.606
60	5.711
65	1.632
70	0.000
75	0.000
80	0.000
85	0.000
90	0.000

IES INDOOR REPORT**PHOTOMETRIC FILENAME : 6DR-TL-L20-835-(L17)-DIM-UNV-OW-OF-CS_.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	535.08	N.A.	31.30
0-30	1265.37	N.A.	74.00
0-40	1665.35	N.A.	97.40
0-60	1707.74	N.A.	99.90
0-80	1709.94	N.A.	100.00
0-90	1709.94	N.A.	100.00
10-90	1581.43	N.A.	92.50
20-40	1130.27	N.A.	66.10
20-50	1161.8	N.A.	67.90
40-70	44.59	N.A.	2.60
60-80	2.20	N.A.	0.10
70-80	0.00	N.A.	0.00
80-90	0.00	N.A.	0.00
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	1709.94	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	128.51
10-20	406.56
20-30	730.29
30-40	399.98
40-50	31.52
50-60	10.87
60-70	2.20
70-80	0.00
80-90	0.00
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 6DR-TL-L20-835-(L17)-DIM-UNV-OW-OF-CS_.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	108	106	111	109	106	104	105	103	101	101	99	98	97	96	95	94
2	108	103	99	96	106	101	98	95	98	95	93	95	93	91	92	90	89	87
3	102	96	91	87	100	95	90	86	92	88	85	90	86	84	87	85	82	81
4	97	90	84	80	95	89	83	79	86	82	79	84	81	78	83	79	77	75
5	92	84	78	74	91	83	77	73	81	76	73	79	75	72	78	74	71	70
6	87	78	72	68	86	78	72	68	76	71	67	75	70	67	73	70	67	65
7	83	74	68	63	82	73	67	63	72	67	63	70	66	62	69	65	62	61
8	79	69	63	59	78	69	63	59	67	62	59	66	62	58	65	61	58	57
9	75	65	59	55	74	65	59	55	64	58	55	63	58	55	62	57	54	53
10	71	61	55	51	70	61	55	51	60	55	51	59	54	51	58	54	51	50


IES INDOOR REPORT
PHOTOMETRIC FILENAME : 6DR-TL-L20-835-(L17)-DIM-UNV-OW-OF-CS_.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
	3H	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
	4H	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
	6H	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
	8H	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
	12H	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
4H	2H	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
	3H	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
	4H	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
	6H	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
	8H	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
	12H	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
8H	4H	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
	6H	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
	8H	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
	12H	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
12H	4H	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
	6H	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
	8H	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9

Maximum UGR = 1.9

POLAR GRAPH



Maximum Candela = 1616.994 Located At Horizontal Angle = 0, Vertical Angle = 25
1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (25) (Through Max. Cd.)