



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : 6DR-TL-L10-840-EM7W-DIM-UNV-OW-OF-CS\_(EMERGENCY MODE).IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002  
 [TEST]GEN FROM BALLABS TEST NO. 20687.0  
 [TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC  
 [ISSUEDATE] 12-29-2020  
 [MANUFAC] WILLIAMS INDOOR  
 [OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO  
 [LUMINAIRE] 1 BRIDGELUX V13 LED 6"RND RECESSED CAST HOUSING DOWNLIGHT  
 [MORE] OPEN SEMI-SPEC SPUN ALUMINUM REFLECTOR (WIDE)  
 [LUMCAT] 6DR-TL-L10-840-EM7W-DIM-UNV-OW-OF-CS (EMER MODE)  
 [LAMPCAT] V13 BXRE-35E2000  
 [ \_SEARCH\_SOURCETYPE] LED  
 [ \_SEARCH\_APPLICATION] Indoor, Architectural, Classroom, Commercial, Healthcare, Office, Downlight  
 [ \_SEARCH\_MOUNTING] Recessed

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	818
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	117
Total Luminaire Watts	7
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	0.98
Basic Luminous Shape	Circular
Luminous Length (0-180)	0.48 ft (Diameter)
Luminous Width (90-270)	0.48 ft (Diameter)
Luminous Height	0.00 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	1516	1516	1516
55	528	528	528
65	110	110	110
75	0	0	0
85	0	0	0

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : 6DR-TL-L10-840-EM7W-DIM-UNV-OW-OF-CS\_(EMERGENCY MODE).IES

## CANDELA TABULATION

	<u>0</u>
0	652.766
5	616.458
10	678.533
15	677.362
20	707.423
25	773.793
30	760.129
35	235.808
40	32.404
45	17.959
50	10.541
55	5.075
60	2.733
65	0.781
70	0.000
75	0.000
80	0.000
85	0.000
90	0.000

**IES INDOOR REPORT****PHOTOMETRIC FILENAME : 6DR-TL-L10-840-EM7W-DIM-UNV-OW-OF-CS\_(EMERGENCY MODE).IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	256.06	N.A.	31.30
0-30	605.53	N.A.	74.00
0-40	796.93	N.A.	97.40
0-60	817.22	N.A.	99.90
0-80	818.27	N.A.	100.00
0-90	818.27	N.A.	100.00
10-90	756.77	N.A.	92.50
20-40	540.88	N.A.	66.10
20-50	555.96	N.A.	67.90
40-70	21.34	N.A.	2.60
60-80	1.05	N.A.	0.10
70-80	0.00	N.A.	0.00
80-90	0.00	N.A.	0.00
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	818.27	N.A.	100.00

Total Luminaire Efficiency = N.A.%

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	61.50
10-20	194.56
20-30	349.47
30-40	191.41
40-50	15.08
50-60	5.20
60-70	1.05
70-80	0.00
80-90	0.00
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : 6DR-TL-L10-840-EM7W-DIM-UNV-OW-OF-CS\_(EMERGENCY MODE).IES

## COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD


Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	108	106	111	109	106	104	105	103	101	101	99	98	97	96	95	94
2	108	103	99	96	106	101	98	95	98	95	93	95	93	91	92	90	89	87
3	103	96	91	87	101	95	90	86	92	88	85	90	86	84	87	85	82	81
4	97	90	84	80	95	89	83	79	86	82	79	84	81	78	83	79	77	75
5	92	84	78	74	91	83	77	73	81	76	73	79	75	72	78	74	71	70
6	87	79	73	68	86	78	72	68	76	71	67	75	70	67	73	70	67	65
7	83	74	68	63	82	73	67	63	72	67	63	70	66	62	69	65	62	61
8	79	69	63	59	78	69	63	59	67	62	59	66	62	58	65	61	58	57
9	75	65	59	55	74	65	59	55	64	58	55	63	58	55	62	58	54	53
10	71	61	55	51	70	61	55	51	60	55	51	59	54	51	58	54	51	50

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : 6DR-TL-L10-840-EM7W-DIM-UNV-OW-OF-CS\_(EMERGENCY MODE).IES

## POLAR GRAPH



Maximum Candela = 773.793 Located At Horizontal Angle = 0, Vertical Angle = 25

# 1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)

# 2 - Horizontal Cone Through Vertical Angle (25) (Through Max. Cd.)