



IES INDOOR REPORT

PHOTOMETRIC FILENAME : 6DR-TL-L15-935-DIM-UNV-OW-OF-CS_.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
 [TEST] GEN FROM BALLABS TEST NO. 20687.0
 [TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC
 [ISSUEDATE] 09-27-2021
 [MANUFAC] WILLIAMS INDOOR
 [OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO
 [LUMINAIRE] 6"RND RECESSED LED DOWNLIGHT
 [MORE] OPEN SEMI-SPEC SPUN ALUMINUM REFLECTOR (WIDE)
 [LUMCAT] 6DR-TL-L15-935-DIM-UNV-OW-OF-CS
 [LAMPCAT] V13 BXRE-35E2000
 [_SEARCH_SOURCETYPE] LED
 [_SEARCH_APPLICATION] Indoor, Commercial, Healthcare, Office, Downlight
 [_SEARCH_MOUNTING] Recessed

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1227
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	89
Total Luminaire Watts	13.8
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	0.98
Basic Luminous Shape	Circular
Luminous Length (0-180)	0.48 ft (Diameter)
Luminous Width (90-270)	0.48 ft (Diameter)
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	2273	2273	2273
55	792	792	792
65	165	165	165
75	0	0	0
85	0	0	0

IES INDOOR REPORT
PHOTOMETRIC FILENAME : 6DR-TL-L15-935-DIM-UNV-OW-OF-CS_.IES

CANDELA TABULATION

	<u>0</u>
0	978.790
5	924.348
10	1017.426
15	1015.670
20	1060.746
25	1160.264
30	1139.775
35	353.582
40	48.588
45	26.928
50	15.806
55	7.610
60	4.098
65	1.171
70	0.000
75	0.000
80	0.000
85	0.000
90	0.000

IES INDOOR REPORT
PHOTOMETRIC FILENAME : 6DR-TL-L15-935-DIM-UNV-OW-OF-CS_.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	383.94	N.A.	31.30
0-30	907.96	N.A.	74.00
0-40	1194.96	N.A.	97.40
0-60	1225.38	N.A.	99.90
0-80	1226.96	N.A.	100.00
0-90	1226.96	N.A.	100.00
10-90	1134.74	N.A.	92.50
20-40	811.02	N.A.	66.10
20-50	833.64	N.A.	67.90
40-70	31.99	N.A.	2.60
60-80	1.58	N.A.	0.10
70-80	0.00	N.A.	0.00
80-90	0.00	N.A.	0.00
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	1226.96	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	92.21
10-20	291.73
20-30	524.01
30-40	287.01
40-50	22.62
50-60	7.80
60-70	1.58
70-80	0.00
80-90	0.00
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : 6DR-TL-L15-935-DIM-UNV-OW-OF-CS_.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	108	106	111	109	106	104	105	103	101	101	99	98	97	96	95	94
2	108	103	99	96	106	101	98	95	98	95	93	95	93	91	92	90	89	87
3	102	96	91	87	100	95	90	86	92	88	85	90	86	84	87	85	82	81
4	97	90	84	80	95	89	83	79	86	82	79	84	81	78	83	79	77	75
5	92	84	78	74	91	83	77	73	81	76	73	79	75	72	78	74	71	70
6	87	78	72	68	86	78	72	68	76	71	67	75	70	67	73	70	67	65
7	83	74	68	63	82	73	67	63	72	67	63	70	66	62	69	65	62	61
8	79	69	63	59	78	69	63	59	67	62	59	66	62	58	65	61	58	57
9	75	65	59	55	74	65	59	55	64	58	55	63	58	55	62	57	54	53
10	71	61	55	51	70	61	55	51	60	55	51	59	54	51	58	54	51	50


IES INDOOR REPORT
PHOTOMETRIC FILENAME : 6DR-TL-L15-935-DIM-UNV-OW-OF-CS_.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size											
		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
	3H	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
	4H	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
	6H	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
	8H	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
	12H	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
4H	2H	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
	3H	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
	4H	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
	6H	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
	8H	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
	12H	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
8H	4H	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
	6H	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
	8H	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
	12H	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
12H	4H	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
	6H	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
	8H	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7

Maximum UGR = 0.7

POLAR GRAPH



Maximum Candela = 1160.264 Located At Horizontal Angle = 0, Vertical Angle = 25
1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (25) (Through Max. Cd.)