



UL Verification Services Inc.
7036 Snowdrift Road
Allentown, PA 18106
610-774-1300



Indoor Distribution Test Report

Relevant Standards
IES LM-79-2008, ANSI C82.77-2002

Prepared For
H E Williams Inc

831 W Fairview Ave
PO Box 837
Carthage, MO 64836-0837
United States

Catalog Number
6DR-L20/835-DIM-UNV-R-W-OF-WH-AD

Order Number
12326812
Test Number
12326812.16

Test Date

2018-06-06

Prepared By

Cordaryl Cousar, Technician

Approved By


Alexa Lambert, Project Handler

The results contained in this report pertain only to the tested sample.
This report shall not be reproduced, except in full, without written approval of Underwriters Laboratories.
This report must not be used by the client to claim product certification, approval, or endorsement by
NVLAP, NIST, or any agency of the Federal Government.



Luminaire Description: Black formed aluminum housing, white reflector, frosted plastic lens enclosure
Lamp: One white LED
Mounting: Recessed
Ballast/Driver: Philips XI025C070V054DSM5

Luminaire



Luminaire Characteristics

Luminous Diameter: 5.75 in.

Summary of Results

Total Luminaire Output:	1282 Lumens
Luminaire Efficacy:	67.2 lm/w
Maximum Candela:	646 Candela

Test Conditions

Test Temperature:	24.9 °C
Voltage:	120.0 VAC
Current:	0.1600 A
Power:	19.08 W
Power Factor:	0.994
Frequency:	60 Hz
Current THD:	9.68 %

Laboratory results may not be representative of field performance
Ballast factors have not been applied



Distribution - Goniophotometer

Distribution Test Conditions


Temperature	Voltage	Current	Power	Power Factor	Frequency	Current THD
24.9 °C	120.0 VAC	0.1600 A	19.08 W	0.994	60 Hz	9.68 %

Summary of Results

Spacing Criteria
 0-180: 1.16
 90-270: 1.16

Total Lumen Output: 1282 Lumens
Luminaire Efficacy: 67.2 lm/w
Maximum Candela: 646 Candela

Polar Plot



Zonal Lumen Summary

Zone	Lumens	% of Luminaire	Zone	Lumens	% of Luminaire	Zone	Lumens	% of Luminaire
0-5	15.4	1.2%	60-65	55.5	4.3%	120-125	0	0.0%
5-10	45.3	3.5%	65-70	39.7	3.1%	125-130	0	0.0%
10-15	73.4	5.7%	70-75	24.5	1.9%	130-135	0	0.0%
15-20	98.3	7.7%	75-80	14.4	1.1%	135-140	0	0.0%
20-25	119.1	9.3%	80-85	7.8	0.6%	140-145	0	0.0%
25-30	132.5	10.3%	85-90	2.4	0.2%	145-150	0	0.0%
30-35	138.0	10.8%	90-95	0	0.0%	150-155	0	0.0%
35-40	134.3	10.5%	95-100	0	0.0%	155-160	0	0.0%
40-45	121.8	9.5%	100-105	0	0.0%	160-165	0	0.0%
45-50	103.8	8.1%	105-110	0	0.0%	165-170	0	0.0%
50-55	85.6	6.7%	110-115	0	0.0%	170-175	0	0.0%
55-60	70.2	5.5%	115-120	0	0.0%	175-180	0	0.0%

Zone	Lumens	% of Luminaire
0-40	756	59.0%
0-60	1138	88.7%
0-90	1282	100.0%
90-180	0	0.0%



Candela Tabulation

Horizontal Angle (Degrees)

Vertical Angle (Degrees)	0	22.5	45	67.5	90	112.5	135	157.5	180	202.5	225	247.5	270	292.5	315	337.5
	0	646.1	646.1	646.1	646.1	646.1	646.1	646.1	646.1	646.1	646.1	646.1	646.1	646.1	646.1	646.1
	5	639.2	639.2	639.2	639.2	639.2	639.2	639.2	639.2	639.2	639.2	639.2	639.2	639.2	639.2	639.2
	10	627.7	627.7	627.7	627.7	627.7	627.7	627.7	627.7	627.7	627.7	627.7	627.7	627.7	627.7	627.7
	15	609.2	609.2	609.2	609.2	609.2	609.2	609.2	609.2	609.2	609.2	609.2	609.2	609.2	609.2	609.2
	20	584.6	584.6	584.6	584.6	584.6	584.6	584.6	584.6	584.6	584.6	584.6	584.6	584.6	584.6	584.6
	25	548.5	548.5	548.5	548.5	548.5	548.5	548.5	548.5	548.5	548.5	548.5	548.5	548.5	548.5	548.5
	30	498.4	498.4	498.4	498.4	498.4	498.4	498.4	498.4	498.4	498.4	498.4	498.4	498.4	498.4	498.4
	35	438.0	438.0	438.0	438.0	438.0	438.0	438.0	438.0	438.0	438.0	438.0	438.0	438.0	438.0	438.0
	40	366.7	366.7	366.7	366.7	366.7	366.7	366.7	366.7	366.7	366.7	366.7	366.7	366.7	366.7	366.7
	45	292.3	292.3	292.3	292.3	292.3	292.3	292.3	292.3	292.3	292.3	292.3	292.3	292.3	292.3	292.3
	50	224.3	224.3	224.3	224.3	224.3	224.3	224.3	224.3	224.3	224.3	224.3	224.3	224.3	224.3	224.3
	55	172.5	172.5	172.5	172.5	172.5	172.5	172.5	172.5	172.5	172.5	172.5	172.5	172.5	172.5	172.5
	60	132.6	132.6	132.6	132.6	132.6	132.6	132.6	132.6	132.6	132.6	132.6	132.6	132.6	132.6	132.6
	65	96.2	96.2	96.2	96.2	96.2	96.2	96.2	96.2	96.2	96.2	96.2	96.2	96.2	96.2	96.2
	70	61.4	61.4	61.4	61.4	61.4	61.4	61.4	61.4	61.4	61.4	61.4	61.4	61.4	61.4	61.4
	75	34.8	34.8	34.8	34.8	34.8	34.8	34.8	34.8	34.8	34.8	34.8	34.8	34.8	34.8	34.8
	80	20.1	20.1	20.1	20.1	20.1	20.1	20.1	20.1	20.1	20.1	20.1	20.1	20.1	20.1	20.1
	85	8.9	8.9	8.9	8.9	8.9	8.9	8.9	8.9	8.9	8.9	8.9	8.9	8.9	8.9	8.9
	90	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1
	95	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	100	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	105	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	110	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	115	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	120	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	125	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	130	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	135	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	140	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	145	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	150	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	155	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	160	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	165	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	170	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	175	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	180	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Average Luminance (cd/m²)

Horizontal Angle (Degrees)


Vertical Angle (Degrees)	0	45	90
	0	38570	38570
	45	24670	24670
	55	17950	17950
	65	13590	13590
	75	8036	8036
	85	6064	6064



Coefficients of Utilization - Zonal Cavity Method

Effective Floor Cavity Reflectance 20%																		
Ceiling Cavity Reflectance	80				70				50			30			10			0
Wall Reflectance	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
Room Cavity Ratio (RCR)	** Values are expressed as percent of total lumen output delivered to the task surface **																	
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	111	107	103	100	108	104	101	98	100	98	95	96	94	92	93	91	90	88
2	102	95	89	84	100	93	88	83	90	85	82	87	83	80	84	81	78	76
3	94	85	78	73	92	84	77	72	81	75	71	78	73	69	76	72	68	66
4	87	77	69	63	85	75	68	63	73	67	62	71	65	61	69	64	60	58
5	81	70	61	56	79	68	61	55	66	60	55	65	59	54	63	58	54	52
6	75	63	55	49	74	62	55	49	61	54	49	59	53	48	58	52	48	46
7	70	58	50	44	69	57	50	44	56	49	44	54	48	44	53	48	43	42
8	66	53	45	40	64	53	45	40	51	45	40	50	44	40	49	43	39	38
9	62	49	42	36	60	49	41	36	48	41	36	47	40	36	46	40	36	34
10	58	46	38	33	57	45	38	33	44	38	33	43	37	33	42	37	33	31


Beam and Field Information	
CIE Type:	Direct
Center Beam Intensity:	646.1 Candela
Central Cone Intensity:	643 Candela
Beam Flux:	829.9 Lumens
Beam Angle (0-180):	85.8 Degrees
Beam Angle (90-270):	85.8 Degrees
Field Angle (0-180):	139.0 Degrees
Field Angle (90-270):	139.0 Degrees





ISOFootcandle Plot

Mounting Height - 8 Feet



Grid Lines in Units of Mounting Height

5 fc 2 fc 1 fc 0.5 fc 0.2 fc 0.1 fc