


BALLABS CERTIFIED TEST REPORT NO.: 20347.0 DATE 04/24/18
PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO
DESCRIPTION: GEN7 V13 LED 6"SHORT HEATSINK 6"SQ CAST HOUSING DOWNLIGHT
WHITE MIXING CHAMBER & 6"ALUM SEMI-SPEC WALL WASH TRIM
w/FROST FILM ADVANCE # XI025C070V054DSM1 @ 560mA
CATALOG NBR: 6DS-L20/835-DIM-UNV-O-WW-OF-CS
LAMP TYPE : BXRE-35E2000

0 DEGREE PLANE CONTAINS MAXIMUM CANDLEPOWER



[Handwritten signature]

NVLAP[®]
TESTING

NVLAP LAB CODE 200921-0

LUMEN SUMMARY							
ZONE	LUMENS	%LAMP	%FIXT	ZONE	LUMENS	%LAMP	%FIXT
0- 30	1210.	NA.	64.7	90-120	0.	NA.	.0
0- 40	1554.	NA.	83.1	90-130	0.	NA.	.0
0- 60	1811.	NA.	96.8	90-150	0.	NA.	.0
0- 90	1870.	NA.	100.0	90-180	0.	NA.	.0
TOTAL LUMINAIRE =				0-180	1870.	NA.	100.0

THIS BALLABS REPORT WITH THE USE OF THE NVLAP LOGO SHALL NOT BE USED BY THIS CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY NVLAP, NIST, OR ANY AGENCY OF THE FEDERAL GOVERNMENT.

BALLABS CERTIFIED TEST REPORT NO.: 20347.0 DATE 04/24/18
 PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO
 DESCRIPTION: GEN7 V13 LED 6"SHORT HEATSINK 6"SQ CAST HOUSING DOWNLIGHT
 WHITE MIXING CHAMBER & 6"ALUM SEMI-SPEC WALL WASH TRIM
 w/FROST FILM ADVANCE # XI025C070V054DSM1 @ 560mA
 CATALOG NBR: 6DS-L20/835-DIM-UNV-O-WW-OF-CS
 LAMP TYPE : BXRE-35E2000

CANDLEPOWER DISTRIBUTION
 0 DEGREE PLANE CONTAINS MAXIMUM CANDLEPOWER

VERT	HORIZONTAL									LUMENS		TOTAL
	.0	22.5	45.0	67.5	90.0	112.5	135.0	157.5	180.0	FRONT	BACK	
0	1948.	1948.	1948.	1948.	1948.	1948.	1948.	1948.	1948.			
5	1972.	1957.	1951.	1932.	1913.	1905.	1908.	1924.	1927.	92.8	91.4	184.2
10	1874.	1864.	1858.	1841.	1815.	1813.	1839.	1850.	1862.			
15	1704.	1687.	1690.	1678.	1659.	1676.	1694.	1680.	1700.	238.4	237.8	476.3
20	1498.	1460.	1486.	1468.	1438.	1468.	1494.	1450.	1427.			
25	1202.	1256.	1218.	1167.	1137.	1200.	1214.	1129.	1078.	280.3	269.5	549.8
30	921.	951.	950.	801.	771.	847.	901.	777.	709.			
35	686.	667.	659.	506.	443.	529.	593.	486.	448.	184.2	159.3	343.5
40	558.	510.	401.	295.	247.	299.	359.	312.	296.			
45	475.	436.	277.	151.	144.	146.	192.	188.	182.	113.8	64.6	178.3
50	380.	346.	158.	77.	60.	65.	87.	90.	95.			
55	325.	265.	76.	32.	18.	23.	29.	31.	32.	66.6	12.0	78.6
60	296.	219.	29.	1.	0.	0.	6.	4.	10.			
65	262.	178.	14.	2.	0.	0.	0.	2.	2.	44.7	.5	45.2
70	184.	114.	8.	0.	0.	0.	0.	0.	0.			
75	103.	54.	1.	0.	0.	0.	0.	0.	0.	14.2	.0	14.2
80	14.	11.	0.	0.	0.	0.	0.	0.	0.			
85	0.	0.	0.	0.	0.	0.	0.	0.	0.	.0	.0	.0
90	0.	0.	0.	0.	0.	0.	0.	0.	0.			

USE .500 FT. AS LENGTH AND .500 FT. AS WIDTH

BALLABS CERTIFIED TEST REPORT NO.: 20347.0 DATE 04/24/18
 PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO
 DESCRIPTION: GEN7 V13 LED 6"SHORT HEATSINK 6"SQ CAST HOUSING DOWNLIGHT
 WHITE MIXING CHAMBER & 6"ALUM SEMI-SPEC WALL WASH TRIM
 w/FROST FILM ADVANCE # XI025C070V054DSM1 @ 560mA
 CATALOG NBR: 6DS-L20/835-DIM-UNV-O-WW-OF-CS
 LAMP TYPE : BXRE-35E2000

ZONAL CAVITY COEFFICIENTS OF UTILIZATION

EFFECTIVE FLOOR CAVITY REFLECTANCE=.20

CEILING	.80				.70				.50				.30				.10				.00
WALL	.70	.50	.30	.10	.70	.50	.30	.10	.50	.30	.10	.50	.30	.10	.50	.30	.10	.50	.30	.10	.00
RCR																					
0	1.19	1.19	1.19	1.19	1.16	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00	1.00	1.00	1.00
1	1.13	1.11	1.08	1.06	1.11	1.08	1.06	1.04	1.04	1.03	1.01	1.01	.99	.98	.97	.96	.95	.93	.93	.93	.93
2	1.08	1.03	.98	.95	1.05	1.01	.97	.94	.98	.94	.92	.95	.92	.90	.92	.90	.88	.86	.86	.86	.86
3	1.02	.95	.90	.86	1.00	.94	.89	.85	.91	.87	.84	.89	.86	.83	.87	.84	.82	.80	.80	.80	.80
4	.96	.89	.83	.78	.95	.87	.82	.78	.85	.81	.77	.83	.79	.76	.81	.78	.75	.74	.74	.74	.74
5	.91	.82	.76	.72	.89	.81	.76	.71	.80	.75	.71	.78	.74	.70	.76	.73	.70	.68	.68	.68	.68
6	.86	.77	.71	.67	.85	.76	.71	.66	.75	.70	.66	.73	.69	.65	.72	.68	.65	.63	.63	.63	.63
7	.82	.72	.66	.62	.80	.72	.66	.61	.70	.65	.61	.69	.64	.61	.68	.64	.60	.59	.59	.59	.59
8	.77	.67	.61	.57	.76	.67	.61	.57	.65	.60	.56	.64	.60	.56	.63	.59	.56	.54	.54	.54	.54
9	.73	.62	.56	.52	.71	.62	.56	.52	.61	.55	.52	.60	.55	.51	.59	.55	.51	.50	.50	.50	.50
10	.68	.58	.52	.48	.67	.58	.52	.48	.57	.51	.48	.56	.51	.47	.55	.51	.47	.46	.46	.46	.46



TESTED IN ACCORDANCE WITH CURRENT IES PROCEDURES

BALLABS CERTIFIED TEST REPORT NO.: 20347.0 DATE 04/24/18
PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO
DESCRIPTION: GEN7 V13 LED 6"SHORT HEATSINK 6"SQ CAST HOUSING DOWNLIGHT
WHITE MIXING CHAMBER & 6"ALUM SEMI-SPEC WALL WASH TRIM
w/FROST FILM ADVANCE # XI025C070V054DSM1 @ 560mA
CATALOG NBR: 6DS-L20/835-DIM-UNV-O-WW-OF-CS
LAMP TYPE : BXRE-35E2000

ELECTRICAL CHARACTERISTICS 120.01V .1891A 22.4550W

LUMINOUS EFFICACY (LUMENS / WATTS) = 83.3

TESTED IN ACCORDANCE WITH CURRENT IES STANDARDS
UTILIZING ABSOLUTE PHOTOMETRY PER LM-79-08



Ø Degree Plane →