



IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L40-940-XXX-DIM-UNV-OW-CS-TD-XX_.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] GEN FROM BALLABS TEST NO. 20687.0

[TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC

[ISSUE DATE] 2-FEB-2021

[MANUFAC] WILLIAMS INDOOR

[OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO

[LUMINAIRE] 1 BRIDGELUX V13 LED 8" ROUND SURFACE CYLINDER

[MORE] OPEN SEMI-SPEC SPUN ALUMINUM REFLECTOR (WIDE)

[LUMCAT] 8CR-TL-L40-940-xxx-DIM-UNV-OW-CS-TD-xx

[LAMPCAT] V13 BXRE-35E2000

[_SEARCH_SOURCE TYPE] LED

[_SEARCH_APPLICATION] Indoor, Architectural, Classroom, Commercial, Healthcare, Office, Downlight

[_SEARCH_MOUNTING] Surface

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	2507
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	66
Total Luminaire Watts	38
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	0.98
Basic Luminous Shape	Circular
Luminous Length (0-180)	0.48 ft (Diameter)
Luminous Width (90-270)	0.48 ft (Diameter)
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	4643	4643	4643
55	1618	1618	1618
65	338	338	338
75	0	0	0
85	0	0	0

IES INDOOR REPORT
PHOTOMETRIC FILENAME : 8CR-TL-L40-940-XXX-DIM-UNV-OW-CS-TD-XX_.IES

CANDELA TABULATION

	<u>0</u>
0	1999.859
5	1888.623
10	2078.801
15	2075.213
20	2167.311
25	2370.646
30	2328.783
35	722.437
40	99.275
45	55.020
50	32.294
55	15.549
60	8.373
65	2.392
70	0.000
75	0.000
80	0.000
85	0.000
90	0.000

IES INDOOR REPORT
PHOTOMETRIC FILENAME : 8CR-TL-L40-940-XXX-DIM-UNV-OW-CS-TD-XX_.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	784.47	N.A.	31.30
0-30	1855.13	N.A.	74.00
0-40	2441.54	N.A.	97.40
0-60	2503.69	N.A.	99.90
0-80	2506.91	N.A.	100.00
0-90	2506.91	N.A.	100.00
10-90	2318.5	N.A.	92.50
20-40	1657.07	N.A.	66.10
20-50	1703.29	N.A.	67.90
40-70	65.37	N.A.	2.60
60-80	3.22	N.A.	0.10
70-80	0.00	N.A.	0.00
80-90	0.00	N.A.	0.00
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	2506.91	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	188.41
10-20	596.06
20-30	1070.66
30-40	586.41
40-50	46.21
50-60	15.93
60-70	3.22
70-80	0.00
80-90	0.00
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L40-940-XXX-DIM-UNV-OW-CS-TD-XX_.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	108	106	111	109	106	104	105	103	101	101	99	98	97	96	95	94
2	108	103	99	96	106	101	98	95	98	95	93	95	93	91	92	90	89	87
3	102	96	91	87	100	95	90	86	92	88	85	90	86	84	87	85	82	81
4	97	90	84	80	95	89	83	79	86	82	79	84	81	78	83	79	77	75
5	92	84	78	74	91	83	77	73	81	76	73	79	75	72	78	74	71	70
6	87	78	72	68	86	78	72	68	76	71	67	75	70	67	73	70	67	65
7	83	74	68	63	82	73	67	63	72	67	63	70	66	62	69	65	62	61
8	79	69	63	59	78	69	63	59	67	62	59	66	62	58	65	61	58	57
9	75	65	59	55	74	65	59	55	64	58	55	63	58	55	62	57	54	53
10	71	61	55	51	70	61	55	51	60	55	51	59	54	51	58	54	51	50


IES INDOOR REPORT
PHOTOMETRIC FILENAME : 8CR-TL-L40-940-XXX-DIM-UNV-OW-CS-TD-XX_.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
	3H	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
	4H	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
	6H	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
	8H	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
	12H	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
4H	2H	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
	3H	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
	4H	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
	6H	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
	8H	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
	12H	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
8H	4H	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
	6H	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
	8H	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
	12H	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
12H	4H	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
	6H	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
	8H	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2

Maximum UGR = 3.2

POLAR GRAPH



Maximum Candela = 2370.646 Located At Horizontal Angle = 0, Vertical Angle = 25
1 - Vertical Plane Through Horizontal Angles (90 - 270)
2 - Horizontal Cone Through Vertical Angle (25) (Through Max. Cd.)