



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L10-835-(L8)-XXX-DIM-UNV-OW-CS-XX\_.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] GEN FROM BALLABS TEST NO. 20687.0

[TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC

[ISSUE DATE] 3-FEB-2021

[MANUFAC] WILLIAMS INDOOR

[OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO 64836

[LUMINAIRE] 1 BRIDGELUX V13 LED 8" ROUND SURFACE CYLINDER

[MORE] OPEN SEMI-SPEC SPUN ALUMINUM REFLECTOR (WIDE)

[LUMCAT] 8CR-TL-L10-835-(L8)-xxx-DIM-UNV-OW-CS-xx

[LAMPCAT] V13 BXRE-35E2000

[\_SEARCH\_SOURCETYPE] LED

[\_SEARCH\_APPLICATION] Indoor, Architectural, Classroom, Commercial, Healthcare, Office, Downlight

[\_SEARCH\_MOUNTING] Surface

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	802
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	107
Total Luminaire Watts	7.5
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	0.98
Basic Luminous Shape	Circular
Luminous Length (0-180)	0.48 ft (Diameter)
Luminous Width (90-270)	0.48 ft (Diameter)
Luminous Height	0.00 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	1485	1485	1485
55	518	518	518
65	108	108	108
75	0	0	0
85	0	0	0

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L10-835-(L8)-XXX-DIM-UNV-OW-CS-XX\_.IES

## CANDELA TABULATION

	<u>0</u>
0	639.763
5	604.178
10	665.017
15	663.869
20	693.332
25	758.380
30	744.988
35	231.111
40	31.759
45	17.601
50	10.331
55	4.974
60	2.678
65	0.765
70	0.000
75	0.000
80	0.000
85	0.000
90	0.000

**IES INDOOR REPORT****PHOTOMETRIC FILENAME : 8CR-TL-L10-835-(L8)-XXX-DIM-UNV-OW-CS-XX\_.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	250.96	N.A.	31.30
0-30	593.47	N.A.	74.00
0-40	781.06	N.A.	97.40
0-60	800.94	N.A.	99.90
0-80	801.97	N.A.	100.00
0-90	801.97	N.A.	100.00
10-90	741.70	N.A.	92.50
20-40	530.11	N.A.	66.10
20-50	544.89	N.A.	67.90
40-70	20.91	N.A.	2.60
60-80	1.03	N.A.	0.10
70-80	0.00	N.A.	0.00
80-90	0.00	N.A.	0.00
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	801.97	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	60.27
10-20	190.68
20-30	342.51
30-40	187.60
40-50	14.78
50-60	5.10
60-70	1.03
70-80	0.00
80-90	0.00
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

# IES INDOOR REPORT


PHOTOMETRIC FILENAME : 8CR-TL-L10-835-(L8)-XXX-DIM-UNV-OW-CS-XX\_.IES

## COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	108	106	111	109	106	104	105	103	101	101	99	98	97	96	95	94
2	108	103	99	96	106	101	98	95	98	95	93	95	93	91	92	90	89	87
3	102	96	91	87	100	95	90	86	92	88	85	90	86	84	87	85	82	81
4	97	90	84	80	95	89	83	79	86	82	79	84	81	78	83	79	77	75
5	92	84	78	74	91	83	77	73	81	76	73	79	75	72	78	74	71	70
6	87	78	72	68	86	78	72	68	76	71	67	75	70	67	73	70	67	65
7	83	74	68	63	82	73	67	63	72	67	63	70	66	62	69	65	62	61
8	79	69	63	59	78	69	63	59	67	62	59	66	62	58	65	61	58	57
9	75	65	59	55	74	65	59	55	64	58	55	63	58	55	62	57	54	53
10	71	61	55	51	70	61	55	51	60	55	51	59	54	51	58	54	51	50

POLAR GRAPH



Maximum Candela = 758.38 Located At Horizontal Angle = 0, Vertical Angle = 25  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270)  
# 2 - Horizontal Cone Through Vertical Angle (25) (Through Max. Cd.)