



IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L100-840-XXX-DIM1-UNV-OW-OF-CS-XX_.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] GEN FROM BALLABS TEST NO. 20687.0

[TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC

[ISSUEDATE] 11-08-2023

[MANUFAC] WILLIAMS INDOOR

[OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO

[LUMINAIRE] 8"RND LED CYLINDER DOWNLIGHT

[MORE] OPEN SEMI-SPEC SPUN ALUMINUM REFLECTOR (WIDE)

[LUMCAT] 8CR-TL-L100-840-xxx-DIM1-UNV-OW-OF-CS-xx

[LAMPCAT] V13 BXRE-35E2000

[_SEARCH_SOURCETYPE] LED

[_SEARCH_APPLICATION] Indoor, Architectural, Classroom, Commercial, Healthcare, Office, Downlight

[_SEARCH_MOUNTING] Pendant

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	10281
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	114
Total Luminaire Watts	89.8
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	0.98
Basic Luminous Shape	Circular
Luminous Length (0-180)	0.48 ft (Diameter)
Luminous Width (90-270)	0.48 ft (Diameter)
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	19042	19042	19042
55	6634	6634	6634
65	1385	1385	1385
75	0	0	0
85	0	0	0

IES INDOOR REPORT
PHOTOMETRIC FILENAME : 8CR-TL-L100-840-XXX-DIM1-UNV-OW-OF-CS-XX_.IES

CANDELA TABULATION

	<u>0</u>
0	8201.255
5	7745.085
10	8524.989
15	8510.274
20	8887.963
25	9721.823
30	9550.146
35	2962.654
40	407.120
45	225.633
50	132.437
55	63.766
60	34.335
65	9.810
70	0.000
75	0.000
80	0.000
85	0.000
90	0.000

IES INDOOR REPORT**PHOTOMETRIC FILENAME : 8CR-TL-L100-840-XXX-DIM1-UNV-OW-OF-CS-XX_.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	3217.04	N.A.	31.30
0-30	7607.75	N.A.	74.00
0-40	10012.57	N.A.	97.40
0-60	10267.42	N.A.	99.90
0-80	10280.64	N.A.	100.00
0-90	10280.64	N.A.	100.00
10-90	9507.97	N.A.	92.50
20-40	6795.53	N.A.	66.10
20-50	6985.04	N.A.	67.90
40-70	268.07	N.A.	2.60
60-80	13.22	N.A.	0.10
70-80	0.00	N.A.	0.00
80-90	0.00	N.A.	0.00
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	10280.64	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	772.67
10-20	2444.38
20-30	4390.71
30-40	2404.82
40-50	189.51
50-60	65.34
60-70	13.22
70-80	0.00
80-90	0.00
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L100-840-XXX-DIM1-UNV-OW-OF-CS-XX_.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	108	106	111	109	106	104	105	103	101	101	99	98	97	96	95	94
2	108	103	99	96	106	101	98	95	98	95	93	95	93	91	92	90	89	87
3	102	96	91	87	100	95	90	86	92	88	85	90	86	84	87	85	82	81
4	97	90	84	80	95	89	83	79	86	82	79	84	81	78	83	79	77	75
5	92	84	78	74	91	83	77	73	81	76	73	79	75	72	78	74	71	70
6	87	78	72	68	86	78	72	68	76	71	67	75	70	67	73	70	67	65
7	83	74	68	63	82	73	67	63	72	67	63	70	66	62	69	65	62	61
8	79	69	63	59	78	69	63	59	67	62	59	66	62	58	65	61	58	57
9	75	65	59	55	74	65	59	55	64	58	55	63	58	55	62	57	54	53
10	71	61	55	51	70	61	55	51	60	55	51	59	54	51	58	54	51	50

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L100-840-XXX-DIM1-UNV-OW-OF-CS-XX_.IES

UGR TABLE - CORRECTED

Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size UGR Viewed Crosswise


X=2H	Y=2H	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1
	3H	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1
	4H	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1
	6H	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1
	8H	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1
	12H	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1

UGR Viewed Endwise

4H	2H	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1
	3H	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1
	4H	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1
	6H	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1
	8H	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1
	12H	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1
8H	4H	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1
	6H	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1
	8H	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1
	12H	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1
12H	4H	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1
	6H	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1
	8H	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1

Maximum UGR = 8.1

POLAR GRAPH



Maximum Candela = 9721.823 Located At Horizontal Angle = 0, Vertical Angle = 25
1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)
2 - Vertical Plane Through Horizontal Angles (5 - 185)
3 - Vertical Plane Through Horizontal Angles (10 - 190)
4 - Horizontal Cone Through Vertical Angle (25) (Through Max. Cd.)