



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L15-835-(L11)-EM10W-XXX-DIM-UNV-OW-CS-XX\_ EM MODE ONLY.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] GEN FROM BALLABS TEST NO. 20687.0

[TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC

[ISSUE DATE] 3-FEB-2021

[MANUFAC] WILLIAMS INDOOR

[OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO

[LUMINAIRE] 1 BRIDGELUX V13 LED 8" ROUND SURFACE CYLINDER

[MORE] OPEN SEMI-SPEC SPUN ALUMINUM REFLECTOR (WIDE)

[LUMCAT] 8CR-TL-L15-835-(L11)-EM10W-xxx-DIM-UNV-OW-CS-xx

[LAMPCAT] V13 BXRE-35E2000

[\_SEARCH\_SOURCETYPE] LED

[\_SEARCH\_APPLICATION] Indoor, Architectural, Classroom, Commercial, Healthcare, Office, Downlight

[\_SEARCH\_MOUNTING] Surface

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1000
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	100
Total Luminaire Watts	10
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	0.98
Basic Luminous Shape	Circular
Luminous Length (0-180)	0.48 ft (Diameter)
Luminous Width (90-270)	0.48 ft (Diameter)
Luminous Height	0.00 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	1852	1852	1852
55	645	645	645
65	135	135	135
75	0	0	0
85	0	0	0

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L15-835-(L11)-EM10W-XXX-DIM-UNV-OW-CS-XX\_ EM MODE ONLY.IES

## CANDELA TABULATION

	<u>0</u>
0	797.710
5	753.340
10	829.198
15	827.767
20	864.504
25	945.611
30	928.912
35	288.168
40	39.599
45	21.947
50	12.882
55	6.202
60	3.340
65	0.954
70	0.000
75	0.000
80	0.000
85	0.000
90	0.000

**IES INDOOR REPORT****PHOTOMETRIC FILENAME : 8CR-TL-L15-835-(L11)-EM10W-XXX-DIM-UNV-OW-CS-XX\_ EM MODE ONLY.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	312.91	N.A.	31.30
0-30	739.98	N.A.	74.00
0-40	973.89	N.A.	97.40
0-60	998.68	N.A.	99.90
0-80	999.96	N.A.	100.00
0-90	999.96	N.A.	100.00
10-90	924.81	N.A.	92.50
20-40	660.98	N.A.	66.10
20-50	679.41	N.A.	67.90
40-70	26.07	N.A.	2.60
60-80	1.29	N.A.	0.10
70-80	0.00	N.A.	0.00
80-90	0.00	N.A.	0.00
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	999.96	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	75.15
10-20	237.76
20-30	427.07
30-40	233.91
40-50	18.43
50-60	6.36
60-70	1.29
70-80	0.00
80-90	0.00
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L15-835-(L11)-EM10W-XXX-DIM-UNV-OW-CS-XX\_ EM MODE ONLY.IES

## COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD


Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	108	106	111	109	106	104	105	103	101	101	99	98	97	96	95	94
2	108	103	99	96	106	101	98	95	98	95	93	95	93	91	92	90	89	87
3	102	96	91	87	100	95	90	86	92	88	85	90	86	84	87	85	82	81
4	97	90	84	80	95	89	83	79	86	82	79	84	81	78	83	79	77	75
5	92	84	78	74	91	83	77	73	81	76	73	79	75	72	78	74	71	70
6	87	78	72	68	86	78	72	68	76	71	67	75	70	67	73	70	67	65
7	83	74	68	63	82	73	67	63	72	67	63	70	66	62	69	65	62	61
8	79	69	63	59	78	69	63	59	67	62	59	66	62	58	65	61	58	57
9	75	65	59	55	74	65	59	55	64	58	55	63	58	55	62	57	54	53
10	71	61	55	51	70	61	55	51	60	55	51	59	54	51	58	54	51	50

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L15-835-(L11)-EM10W-XXX-DIM-UNV-OW-CS-XX\_ EM MODE ONLY.IES

## POLAR GRAPH



Maximum Candela = 945.611 Located At Horizontal Angle = 0, Vertical Angle = 25

# 1 - Vertical Plane Through Horizontal Angles (90 - 270)

# 2 - Horizontal Cone Through Vertical Angle (25) (Through Max. Cd.)