



IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L10-935-(L6)-EM7W-XXX-DIM-UNV-OW-CS-XX_ EM MODE ONLY.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] GEN FROM BALLABS TEST NO. 20687.0

[TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC

[ISSUEDATE] 4-FEB-2021

[MANUFAC] WILLIAMS INDOOR

[OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO 64836

[LUMINAIRE] 1 BRIDGELUX V13 LED 8" ROUND SURFACE CYLINDER

[MORE] OPEN SEMI-SPEC SPUN ALUMINUM REFLECTOR (WIDE)

[LUMCAT] 8CR-TL-L10-935-(L6)-EM7W-xxx-DIM-UNV-OW-CS-xx EM MODE ONLY

[LAMPCAT] V13 BXRE-35E2000

[_SEARCH_SOURCETYPE] LED

[_SEARCH_APPLICATION] Indoor, Architectural, Classroom, Commercial, Healthcare, Office, Downlight

[_SEARCH_MOUNTING] Surface

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	700
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	100
Total Luminaire Watts	7
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	0.98
Basic Luminous Shape	Circular
Luminous Length (0-180)	0.48 ft (Diameter)
Luminous Width (90-270)	0.48 ft (Diameter)
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	1297	1297	1297
55	452	452	452
65	94	94	94
75	0	0	0
85	0	0	0

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L10-935-(L6)-EM7W-XXX-DIM-UNV-OW-CS-XX_ EM MODE ONLY.IES

CANDELA TABULATION

	<u>0</u>
0	558.397
5	527.338
10	580.439
15	579.437
20	605.153
25	661.928
30	650.239
35	201.718
40	27.719
45	15.363
50	9.017
55	4.342
60	2.338
65	0.668
70	0.000
75	0.000
80	0.000
85	0.000
90	0.000

IES INDOOR REPORT**PHOTOMETRIC FILENAME : 8CR-TL-L10-935-(L6)-EM7W-XXX-DIM-UNV-OW-CS-XX_ EM MODE ONLY.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	219.04	N.A.	31.30
0-30	517.99	N.A.	74.00
0-40	681.72	N.A.	97.40
0-60	699.08	N.A.	99.90
0-80	699.98	N.A.	100.00
0-90	699.98	N.A.	100.00
10-90	647.37	N.A.	92.50
20-40	462.69	N.A.	66.10
20-50	475.59	N.A.	67.90
40-70	18.25	N.A.	2.60
60-80	0.90	N.A.	0.10
70-80	0.00	N.A.	0.00
80-90	0.00	N.A.	0.00
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	699.98	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	52.61
10-20	166.43
20-30	298.95
30-40	163.74
40-50	12.90
50-60	4.45
60-70	0.90
70-80	0.00
80-90	0.00
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L10-935-(L6)-EM7W-XXX-DIM-UNV-OW-CS-XX_ EM MODE ONLY.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD


Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	108	106	111	109	106	104	105	103	101	101	99	98	97	96	95	94
2	108	103	99	96	106	101	98	95	98	95	93	95	93	91	92	90	89	87
3	102	96	91	87	100	95	90	86	92	88	85	90	86	84	87	85	82	81
4	97	90	84	80	95	89	83	79	86	82	79	84	81	78	83	79	77	75
5	92	84	78	74	91	83	77	73	81	76	73	79	75	72	78	74	71	70
6	87	78	72	68	86	78	72	68	76	71	67	75	70	67	73	70	67	65
7	83	74	68	63	82	73	67	63	72	67	63	70	66	62	69	65	62	61
8	79	69	63	59	78	69	63	59	67	62	59	66	62	58	65	61	58	57
9	75	65	59	55	74	65	59	55	64	58	55	63	58	55	62	57	54	53
10	71	61	55	51	70	61	55	51	60	55	51	59	54	51	58	54	51	50

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L10-935-(L6)-EM7W-XXX-DIM-UNV-OW-CS-XX_ EM MODE ONLY.IES

POLAR GRAPH



Maximum Candela = 661.928 Located At Horizontal Angle = 0, Vertical Angle = 25

1 - Vertical Plane Through Horizontal Angles (90 - 270)

2 - Horizontal Cone Through Vertical Angle (25) (Through Max. Cd.)