



IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L30-940-XXX-DIM-UNV-OW-CS-XX_.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] GEN FROM BALLABS TEST NO. 20687.0

[TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC

[ISSUEDATE] 2-FEB-2021

[MANUFAC] WILLIAMS INDOOR

[OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO

[LUMINAIRE] LED 8" ROUND SURFACE CYLINDER

[MORE] OPEN SEMI-SPEC SPUN ALUMINUM REFLECTOR (WIDE)

[LUMCAT] 8CR-TL-L30-940-xxx-DIM-UNV-OW-CS-xx

[LAMPCAT] V13 BXRE-35E2000

[_SEARCH_SOURCETYPE] LED

[_SEARCH_APPLICATION] Indoor, Architectural, Classroom, Commercial, Healthcare, Office, Downlight

[_SEARCH_MOUNTING] Surface

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	2786
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	104
Total Luminaire Watts	26.9
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	0.98
Basic Luminous Shape	Circular
Luminous Length (0-180)	0.48 ft (Diameter)
Luminous Width (90-270)	0.48 ft (Diameter)
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	5160	5160	5160
55	1798	1798	1798
65	375	375	375
75	0	0	0
85	0	0	0

IES INDOOR REPORT
PHOTOMETRIC FILENAME : 8CR-TL-L30-940-XXX-DIM-UNV-OW-CS-XX_.IES

CANDELA TABULATION

	<u>0</u>
0	2222.419
5	2098.804
10	2310.146
15	2306.159
20	2408.507
25	2634.470
30	2587.949
35	802.836
40	110.323
45	61.143
50	35.888
55	17.280
60	9.304
65	2.658
70	0.000
75	0.000
80	0.000
85	0.000
90	0.000

IES INDOOR REPORT**PHOTOMETRIC FILENAME : 8CR-TL-L30-940-XXX-DIM-UNV-OW-CS-XX_.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	871.77	N.A.	31.30
0-30	2061.59	N.A.	74.00
0-40	2713.26	N.A.	97.40
0-60	2782.32	N.A.	99.90
0-80	2785.9	N.A.	100.00
0-90	2785.9	N.A.	100.00
10-90	2576.52	N.A.	92.50
20-40	1841.49	N.A.	66.10
20-50	1892.84	N.A.	67.90
40-70	72.64	N.A.	2.60
60-80	3.58	N.A.	0.10
70-80	0.00	N.A.	0.00
80-90	0.00	N.A.	0.00
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	2785.9	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	209.38
10-20	662.39
20-30	1189.82
30-40	651.67
40-50	51.35
50-60	17.71
60-70	3.58
70-80	0.00
80-90	0.00
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L30-940-XXX-DIM-UNV-OW-CS-XX_.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	108	106	111	109	106	104	105	103	101	101	99	98	97	96	95	94
2	108	103	99	96	106	101	98	95	98	95	93	95	93	91	92	90	89	87
3	102	96	91	87	100	95	90	86	92	88	85	90	86	84	87	85	82	81
4	97	90	84	80	95	89	83	79	86	82	79	84	81	78	83	79	77	75
5	92	84	78	74	91	83	77	73	81	76	73	79	75	72	78	74	71	70
6	87	78	72	68	86	78	72	68	76	71	67	75	70	67	73	70	67	65
7	83	74	68	63	82	73	67	63	72	67	63	70	66	62	69	65	62	61
8	79	69	63	59	78	69	63	59	67	62	59	66	62	58	65	61	58	57
9	75	65	59	55	74	65	59	55	64	58	55	63	58	55	62	57	54	53
10	71	61	55	51	70	61	55	51	60	55	51	59	54	51	58	54	51	50

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L30-940-XXX-DIM-UNV-OW-CS-XX_.IES

UGR TABLE - CORRECTED

Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size UGR Viewed Crosswise


X=2H	Y=2H	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6
	3H	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6
	4H	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6
	6H	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6
	8H	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6
	12H	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6

UGR Viewed Endwise

4H	2H	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6
	3H	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6
	4H	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6
	6H	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6
	8H	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6
	12H	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6
8H	4H	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6
	6H	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6
	8H	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6
	12H	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6
12H	4H	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6
	6H	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6
	8H	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6

Maximum UGR = 3.6

POLAR GRAPH



Maximum Candela = 2634.47 Located At Horizontal Angle = 0, Vertical Angle = 25
1 - Vertical Plane Through Horizontal Angles (90 - 270)
2 - Horizontal Cone Through Vertical Angle (25) (Through Max. Cd.)