



IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L50-835-XXX-DIM-UNV-OW-BL-XX_.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] GEN FROM BALLABS TEST NO. 20687.0

[TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC

[ISSUEDATE] 2-FEB-2021

[MANUFAC] WILLIAMS INDOOR

[OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO

[LUMINAIRE] 1 BRIDGELUX V13 LED 8" ROUND SURFACE CYLINDER

[MORE] OPEN SPUN ALUMINUM REFLECTOR (WIDE)

[LUMCAT] 8CR-TL-L50-835-xxx-DIM-UNV-OW-BL-xx

[LAMPCAT] V13 BXRE-35E2000

[_SEARCH_SOURCETYPE] LED

[_SEARCH_APPLICATION] Indoor, Architectural, Classroom, Commercial, Healthcare, Office, Downlight

[_SEARCH_MOUNTING] Surface

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	2356
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	54
Total Luminaire Watts	43.9
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	0.98
Basic Luminous Shape	Circular
Luminous Length (0-180)	0.48 ft (Diameter)
Luminous Width (90-270)	0.48 ft (Diameter)
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	4365	4365	4365
55	1521	1521	1521
65	318	318	318
75	0	0	0
85	0	0	0

IES INDOOR REPORT
PHOTOMETRIC FILENAME : 8CR-TL-L50-835-XXX-DIM-UNV-OW-BL-XX_.IES

CANDELA TABULATION

	<u>0</u>
0	1879.868
5	1775.306
10	1954.073
15	1950.700
20	2037.273
25	2228.408
30	2189.057
35	679.091
40	93.319
45	51.719
50	30.357
55	14.616
60	7.870
65	2.249
70	0.000
75	0.000
80	0.000
85	0.000
90	0.000

IES INDOOR REPORT**PHOTOMETRIC FILENAME : 8CR-TL-L50-835-XXX-DIM-UNV-OW-BL-XX_.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	737.40	N.A.	31.30
0-30	1743.83	N.A.	74.00
0-40	2295.05	N.A.	97.40
0-60	2353.47	N.A.	99.90
0-80	2356.5	N.A.	100.00
0-90	2356.5	N.A.	100.00
10-90	2179.39	N.A.	92.50
20-40	1557.65	N.A.	66.10
20-50	1601.09	N.A.	67.90
40-70	61.45	N.A.	2.60
60-80	3.03	N.A.	0.10
70-80	0.00	N.A.	0.00
80-90	0.00	N.A.	0.00
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	2356.5	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	177.11
10-20	560.29
20-30	1006.43
30-40	551.23
40-50	43.44
50-60	14.98
60-70	3.03
70-80	0.00
80-90	0.00
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L50-835-XXX-DIM-UNV-OW-BL-XX_.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	108	106	111	109	106	104	105	103	101	101	99	98	97	96	95	94
2	108	103	99	96	106	101	98	95	98	95	93	95	93	91	92	90	89	87
3	103	96	91	87	101	95	90	86	92	88	85	90	86	84	87	85	82	81
4	97	90	84	80	95	89	83	79	86	82	79	84	81	78	83	79	77	75
5	92	84	78	74	91	83	77	73	81	76	73	79	75	72	78	74	71	70
6	87	79	73	68	86	78	72	68	76	71	67	75	70	67	73	70	67	65
7	83	74	68	63	82	73	67	63	72	67	63	70	66	62	69	65	62	61
8	79	69	63	59	78	69	63	59	67	62	59	66	62	58	65	61	58	57
9	75	65	59	55	74	65	59	55	64	58	55	63	58	55	62	58	54	53
10	71	61	55	51	70	61	55	51	60	55	51	59	54	51	58	54	51	50

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L50-835-XXX-DIM-UNV-OW-BL-XX_.IES

UGR TABLE - CORRECTED

Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size UGR Viewed Crosswise


X=2H	Y=2H	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
	3H	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
	4H	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
	6H	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
	8H	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
	12H	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0

UGR Viewed Endwise

4H	2H	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
	3H	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
	4H	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
	6H	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
	8H	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
	12H	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
8H	4H	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
	6H	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
	8H	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
	12H	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
12H	4H	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
	6H	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
	8H	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0

Maximum UGR = 3.0

POLAR GRAPH



Maximum Candela = 2228.408 Located At Horizontal Angle = 0, Vertical Angle = 25
1 - Vertical Plane Through Horizontal Angles (90 - 270)
2 - Horizontal Cone Through Vertical Angle (25) (Through Max. Cd.)