



IES INDOOR REPORT

PHOTOMETRIC FILENAME : LLM-8-P9-8TW-X-SQ-XX-XX-POE 4000K_.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
 [TEST] GEN from BALLABS TEST NO. 17322.0
 [TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC
 [ISSUE DATE] 11-AUG-2021
 [MANUFAC] H.E. WILLIAMS, INC - CARTHAGE, MO
 [LUMINAIRE] 8' DIRECT/INDIRECT SURFACE LUMINAIRE
 [MORE] WHITE REFLECTOR w/FROSTED ACRYLIC SQUARE LENS
 [LUMCAT] LLM-8-P9-8TW-S-SQ-xx-xx-PoE 4000k

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	6998
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	143
Total Luminaire Watts	49.1
Ballast Factor	1.00
CIE Type	Semi-Direct
Spacing Criterion (0-180)	1.10
Spacing Criterion (90-270)	1.18
Spacing Criterion (Diagonal)	1.28
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	7.75 ft
Luminous Width (90-270)	0.21 ft
Luminous Height	0.20 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	9077	6730	6718
55	7279	5625	6014
65	5855	4856	5415
75	4402	4041	4479
85	3253	3512	3792

IES INDOOR REPORT
 PHOTOMETRIC FILENAME : LLM-8-P9-8TW-X-SQ-XX-XX-POE 4000K_.IES

CANDELA TABULATION

	<u>0.0</u>	<u>22.5</u>	<u>45.0</u>	<u>67.5</u>	<u>90.0</u>
0	2134.750	2134.750	2134.750	2134.750	2134.750
5	2143.330	2146.762	2153.626	2153.626	2158.775
10	2083.269	2091.849	2102.145	2109.010	2109.010
15	1976.875	1995.751	2009.479	2016.344	2019.776
20	1896.221	1923.678	1942.554	1956.282	1957.998
25	1707.457	1741.778	1769.234	1788.111	1794.975
30	1532.421	1578.754	1616.507	1650.828	1666.272
35	1377.978	1436.323	1496.384	1554.730	1578.754
40	1168.621	1244.127	1335.077	1422.595	1460.348
45	986.721	1079.387	1206.374	1336.793	1389.990
50	808.253	919.796	1072.523	1233.831	1297.324
55	648.662	773.933	960.981	1148.029	1220.102
60	511.379	645.230	849.438	1050.215	1124.004
65	391.256	535.404	763.636	972.993	1043.351
70	281.430	432.441	665.822	864.883	928.376
75	187.048	336.343	561.144	737.896	791.093
80	113.258	267.702	483.922	646.946	691.563
85	54.913	202.492	408.417	552.564	588.601
90	8.580	133.851	308.887	420.429	446.170
95	0.000	126.987	295.158	392.972	413.565
100	0.000	118.407	264.270	344.923	362.084
105	0.000	111.542	238.529	307.171	320.899
110	0.000	101.246	216.221	276.282	293.442
115	0.000	92.666	195.628	248.825	264.270
120	0.000	89.234	178.468	235.097	247.109
125	0.000	82.370	161.307	209.357	224.801
130	0.000	75.506	145.863	192.196	204.208
135	0.000	68.641	130.419	168.172	183.616
140	0.000	66.925	123.555	159.591	171.604
145	0.000	68.641	114.974	152.727	161.307
150	0.000	56.629	94.382	120.123	130.419
155	0.000	56.629	85.802	108.110	113.258
160	0.000	46.333	70.358	87.518	92.666
165	0.000	41.185	63.493	70.358	73.790
170	0.000	0.000	48.049	60.061	61.777
175	0.000	0.000	22.308	42.901	42.901
180	0.000	0.000	0.000	0.000	0.000

IES INDOOR REPORT
PHOTOMETRIC FILENAME : LLM-8-P9-8TW-X-SQ-XX-XX-POE 4000K_.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	771.71	N.A.	11.00
0-30	1586.75	N.A.	22.70
0-40	2514.24	N.A.	35.90
0-60	4297.21	N.A.	61.40
0-80	5604.26	N.A.	80.10
0-90	6003.81	N.A.	85.80
10-90	5800.5	N.A.	82.90
20-40	1742.53	N.A.	24.90
20-50	2670.5	N.A.	38.20
40-70	2520.8	N.A.	36.00
60-80	1307.05	N.A.	18.70
70-80	569.22	N.A.	8.10
80-90	399.55	N.A.	5.70
90-110	493.04	N.A.	7.00
90-120	661.02	N.A.	9.40
90-130	788.66	N.A.	11.30
90-150	942.63	N.A.	13.50
90-180	994.62	N.A.	14.20
110-180	501.58	N.A.	7.20
0-180	6998.44	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	203.31
10-20	568.40
20-30	815.04
30-40	927.49
40-50	927.97
50-60	855.00
60-70	737.83
70-80	569.22
80-90	399.55
90-100	275.74
100-110	217.30
110-120	167.98
120-130	127.64
130-140	90.66
140-150	63.31
150-160	34.98
160-170	14.73
170-180	2.28

IES INDOOR REPORT

PHOTOMETRIC FILENAME : LLM-8-P9-8TW-X-SQ-XX-XX-POE 4000K_.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	115	115	115	115	110	110	110	110	102	102	102	95	95	95	88	88	88	85
1	103	97	92	88	99	94	89	85	87	83	80	81	78	75	75	73	70	67
2	93	84	77	71	89	81	74	69	75	70	65	70	65	62	65	61	58	55
3	85	74	65	58	81	71	63	57	66	60	54	61	56	52	57	53	49	46
4	77	65	56	49	74	63	55	48	59	52	46	55	49	44	51	46	42	39
5	71	58	49	42	68	56	48	42	53	45	40	49	43	38	46	41	36	34
6	66	52	43	37	63	51	42	36	48	40	35	45	38	34	42	36	32	30
7	61	48	39	33	58	46	38	32	43	36	31	41	34	30	38	33	29	26
8	57	43	35	29	54	42	34	29	40	33	28	37	31	27	35	30	26	24
9	53	40	32	26	51	39	31	26	37	30	25	34	28	24	33	27	23	21
10	50	37	29	24	48	36	28	23	34	27	23	32	26	22	30	25	21	19

IES INDOOR REPORT

PHOTOMETRIC FILENAME : LLM-8-P9-8TW-X-SQ-XX-XX-POE 4000K_.IES

UGR TABLE - CORRECTED

Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size UGR Viewed Crosswise

X=2H	Y=2H	14.2	15.6	14.8	16.2	16.8	19.3	20.7	19.8	21.2	21.9
	3H	15.4	16.6	15.9	17.2	17.9	22.0	23.3	22.6	23.9	24.6
	4H	15.7	16.9	16.3	17.5	18.2	23.3	24.5	23.9	25.1	25.8
	6H	15.9	17.0	16.5	17.6	18.3	24.7	25.8	25.3	26.4	27.1
	8H	15.9	17.0	16.5	17.6	18.3	25.4	26.5	26.0	27.1	27.8
	12H	15.9	16.9	16.5	17.6	18.3	26.2	27.2	26.8	27.8	28.6

UGR Viewed Endwise


4H	2H	15.6	16.8	16.2	17.4	18.1	19.5	20.7	20.1	21.3	22.0
	3H	17.0	18.0	17.6	18.7	19.4	22.5	23.5	23.1	24.1	24.8
	4H	17.5	18.4	18.1	19.0	19.8	23.9	24.9	24.5	25.5	26.2
	6H	17.8	18.6	18.4	19.3	20.0	25.4	26.3	26.1	27.0	27.7
	8H	17.8	18.6	18.5	19.3	20.1	26.3	27.0	26.9	27.7	28.5
	12H	17.9	18.6	18.6	19.3	20.1	27.2	27.9	27.8	28.6	29.3

8H	4H	18.6	19.4	19.2	20.0	20.8	24.0	24.8	24.7	25.5	26.2
	6H	19.1	19.8	19.8	20.5	21.3	25.7	26.4	26.4	27.1	27.8
	8H	19.3	19.9	20.0	20.6	21.4	26.6	27.2	27.3	27.9	28.7
	12H	19.4	19.9	20.1	20.6	21.5	27.7	28.2	28.4	28.9	29.8

12H	4H	18.9	19.6	19.6	20.3	21.1	24.0	24.7	24.7	25.4	26.2
	6H	19.6	20.2	20.3	20.9	21.7	25.7	26.3	26.4	27.0	27.8
	8H	19.9	20.4	20.6	21.1	22.0	26.7	27.2	27.4	27.9	28.8

Maximum UGR = 29.8

POLAR GRAPH



Maximum Candela = 2158.775 Located At Horizontal Angle = 90, Vertical Angle = 5
1 - Vertical Plane Through Horizontal Angles (90 - 270)
2 - Horizontal Cone Through Vertical Angle (5) (Through Max. Cd.)