H.E. WILLIAMS, INC.

IES INDOOR REPORT
PHOTOMETRIC FILENAME : PT-24-L49-830-RA-DIM-UNV_.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
[TEST] GEN FROM BALLABS TEST NO. 19235.0
[TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC
[ISSUEDATE] 2023-06-27
[MANUFAC] WILLIAMS INDOOR
[OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO
[LUMINAIRE] 2x4' RECESSED LED LUMINAIRE
[MORE] WHITE REFLECTOR w/RIBBED FROSTED ACRYLIC CENTER DIFFUSER
[MORE] 0-10V DRIVER
[LUMCAT] PT-24-L49-830-RA-DIM-UNV
[LAMPCAT] 22 INCH HLM LED ARRAYS
[_SEARCH_SOURCETYPE] LED
[_SEARCH_APPLICATION] Indoor, Architectural, Office, Direct
[_SEARCH_MOUNTING] Recessed

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	5027
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	137
Total Luminaire Watts	36.7
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.14
Spacing Criterion (90-270)	1.18
Spacing Criterion (Diagonal)	1.28
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.92 ft
Luminous Width (90-270)	1.92 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	2156	2275	2391
55	1933	2115	2285
65	1699	2013	2287
75	1315	2019	2499
85	794	2649	3035

Photometric Toolbox (R) Copyright 2002-2019 by Lighting Analysts, Inc.
Calculations based on published IES Methods and recommendations, values rounded for display purposes.
Results derived from content of manufacturers photometric file.

IES INDOOR REPORT
PHOTOMETRIC FILENAME : PT-24-L49-830-RA-DIM-UNV_.IES

CANDELA TABULATION

	0.0	22.5	45.0	67.5	90.0
0	1923.305	1923.305	1923.305	1923.305	1923.305
5	1893.937	1891.326	1891.326	1884.800	1881.537
10	1888.063	1888.063	1891.326	1893.937	1893.937
15	1838.463	1841.074	1844.337	1848.905	1852.168
20	1717.074	1723.600	1731.431	1741.874	1745.137
25	1619.831	1625.705	1641.368	1655.074	1661.600
30	1419.474	1375.747	1554.568	1503.010	1495.179
35	1309.179	1321.579	1350.947	1375.747	1385.537
40	1164.947	1180.610	1213.242	1245.874	1258.274
45	1064.442	1078.147	1123.179	1164.947	1180.610
50	924.779	946.316	995.916	1039.642	1054.653
55	774.021	797.516	847.116	896.716	914.989
60	631.095	655.895	712.021	762.926	781.853
65	501.221	533.853	593.895	653.284	674.821
70	369.389	407.895	479.032	541.684	563.221
75	237.558	285.200	364.821	428.126	451.621
80	130.526	192.526	283.895	345.895	364.821
85	48.295	110.295	161.200	181.432	184.695
90	0.000	0.000	0.000	0.000	0.000

Photometric Toolbox (R) Copyright 2002-2019 by Lighting Analysts, Inc.
Calculations based on published IES Methods and recommendations, values rounded for display purposes.
Results derived from content of manufacturers photometric file.

IES INDOOR REPORT
PHOTOMETRIC FILENAME : PT-24-L49-830-RA-DIM-UNV_.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	697.19	N.A.	13.90
0-30	1444.93	N.A.	28.70
0-40	2287.83	N.A.	45.50
0-60	3907.13	N.A.	77.70
0-80	4877.00	N.A.	97.00
0-90	5027.35	N.A.	100.00
10-90	4846.56	N.A.	96.40
20-40	1590.64	N.A.	31.60
20-50	2450.38	N.A.	48.70
40-70	2205.63	N.A.	43.90
60-80	969.88	N.A.	19.30
70-80	383.54	N.A.	7.60
80-90	150.34	N.A.	3.00
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	5027.35	N.A.	100.00

Total Luminaire Efficiency = N.A.%

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	180.79
10-20	516.40
20-30	747.74
30-40	842.90
40-50	859.74
50-60	759.56
60-70	586.34
70-80	383.54
80-90	150.34
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

Photometric Toolbox (R) Copyright 2002-2019 by Lighting Analysts, Inc.
Calculations based on published IES Methods and recommendations, values rounded for display purposes.
Results derived from content of manufacturers photometric file.

IES INDOOR REPORT
PHOTOMETRIC FILENAME : PT-24-L49-830-RA-DIM-UNV_.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	103	99	95	106	101	97	93	97	93	90	93	90	88	89	87	85	83
2	98	90	83	77	96	88	82	76	85	79	74	81	77	73	78	74	71	69
3	90	79	71	64	87	78	70	64	75	68	63	72	66	61	69	64	60	58
4	82	70	61	55	80	69	61	54	66	59	53	64	58	53	62	56	52	50
5	76	63	54	47	74	62	53	47	60	52	46	58	51	46	56	50	45	43
6	70	57	48	41	68	56	47	41	54	46	41	52	46	40	51	45	40	38
7	65	52	43	37	63	51	42	37	49	42	36	48	41	36	46	40	36	34
8	61	47	39	33	59	46	38	33	45	38	32	44	37	32	43	37	32	30
9	57	43	35	30	55	43	35	30	42	34	29	41	34	29	40	33	29	27
10	53	40	32	27	52	40	32	27	39	32	27	38	31	27	37	31	27	25

Photometric Toolbox (R) Copyright 2002-2019 by Lighting Analysts, Inc.
Calculations based on published IES Methods and recommendations, values rounded for display purposes.
Results derived from content of manufacturers photometric file.

IES INDOOR REPORT
PHOTOMETRIC FILENAME : PT-24-L49-830-RA-DIM-UNV_.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	13.9	15.6	14.3	15.9	16.2	15.0	16.6	15.3	16.9	17.2
	3H	15.6	17.1	16.0	17.4	17.8	17.1	18.6	17.5	19.0	19.3
	4H	16.2	17.6	16.6	17.9	18.3	18.1	19.5	18.5	19.9	20.3
	6H	16.5	17.9	17.0	18.2	18.6	19.2	20.5	19.6	20.8	21.2
	8H	16.7	17.9	17.1	18.3	18.7	19.6	20.8	20.0	21.2	21.6
	12H	16.7	17.9	17.2	18.3	18.7	19.9	21.1	20.4	21.5	21.9
4H	2H	14.7	16.1	15.1	16.5	16.9	15.5	16.9	15.9	17.3	17.6
	3H	16.6	17.8	17.1	18.2	18.6	18.0	19.2	18.4	19.6	19.9
	4H	17.3	18.4	17.8	18.8	19.3	19.1	20.2	19.6	20.6	21.1
	6H	17.9	18.8	18.3	19.3	19.7	20.4	21.3	20.8	21.8	22.2
	8H	18.0	18.9	18.5	19.4	19.8	20.9	21.8	21.4	22.2	22.7
	12H	18.2	19.0	18.7	19.4	19.9	21.3	22.1	21.8	22.6	23.1
8H	4H	17.9	18.8	18.4	19.3	19.7	19.5	20.4	19.9	20.8	21.3
	6H	18.7	19.4	19.2	19.9	20.4	20.9	21.7	21.4	22.2	22.6
	8H	19.0	19.6	19.5	20.1	20.6	21.6	22.3	22.1	22.8	23.2
	12H	19.2	19.8	19.7	20.3	20.8	22.2	22.7	22.7	23.2	23.8
12H	4H	18.1	18.9	18.6	19.4	19.8	19.5	20.3	20.0	20.8	21.3
	6H	18.9	19.6	19.5	20.1	20.6	21.0	21.7	21.6	22.2	22.7
	8H	19.3	19.9	19.8	20.4	21.0	21.8	22.3	22.3	22.8	23.4

Maximum UGR = 23.8

Photometric Toolbox (R) Copyright 2002-2019 by Lighting Analysts, Inc.
Calculations based on published IES Methods and recommendations, values rounded for display purposes.
Results derived from content of manufacturers photometric file.

IES INDOOR REPORT
PHOTOMETRIC FILENAME : PT-24-L49-830-RA-DIM-UNV_.IES

POLAR GRAPH



Maximum Candela = 1923.305 Located At Horizontal Angle = 0, Vertical Angle = 0
1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (0) (Through Max. Cd.)

Photometric Toolbox (R) Copyright 2002-2019 by Lighting Analysts, Inc.
Calculations based on published IES Methods and recommendations, values rounded for display purposes.
Results derived from content of manufacturers photometric file.