



IES INDOOR REPORT

PHOTOMETRIC FILENAME : PTDC-22-L43-840-RA-DIM-UNV_.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
 [TEST] GEN FROM BALLABS TEST NO. 19562.0
 [TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC
 [ISSUEDATE] 2022-05-03
 [MANUFAC] WILLIAMS INDOOR
 [OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO
 [LUMINAIRE] 1-72 LED 22"ARRAY 2x2'RECESSED LUMINAIRE
 [MORE] WHITE REFLECTOR w/CENTER FROSTED RIBBED ACRYLIC LENS
 [MORE] ELECTRONIC 0-10V LED DRIVER
 [LUMCAT] PTDC-22-L43-840-RA-DIM-UNV
 [LAMPCAT] HLM 80 CRI 4000K CCT
 [SEARCH_SOURCETYPE] LED
 [SEARCH_APPLICATION] INDOOR
 [SEARCH_MOUNTING] RECESSED

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	4473
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	129
Total Luminaire Watts	34.7
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.24
Spacing Criterion (90-270)	1.24
Spacing Criterion (Diagonal)	1.34
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	1.92 ft
Luminous Width (90-270)	1.93 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	4203	4359	4501
55	3553	3915	4178
65	2716	3397	3777
75	1888	3013	3724
85	1075	2458	3072

IES INDOOR REPORT
PHOTOMETRIC FILENAME : PTDC-22-L43-840-RA-DIM-UNV_.IES

CANDELA TABULATION

	<u>0.0</u>	<u>22.5</u>	<u>45.0</u>	<u>67.5</u>	<u>90.0</u>
0	1709.530	1709.530	1709.530	1709.530	1709.530
5	1715.278	1704.931	1702.632	1696.883	1696.883
10	1692.285	1681.938	1680.788	1675.040	1673.890
15	1652.047	1640.551	1639.401	1637.102	1635.952
20	1594.565	1584.218	1583.068	1584.218	1584.218
25	1514.089	1503.742	1510.640	1515.239	1510.640
30	1415.219	1410.621	1417.518	1425.566	1419.818
35	1301.404	1300.254	1315.200	1320.948	1326.696
40	1170.344	1170.344	1195.636	1205.983	1215.180
45	1020.889	1020.889	1058.828	1082.970	1093.317
50	863.387	864.537	915.121	947.312	962.257
55	700.137	712.783	771.415	805.905	823.149
60	540.335	565.628	624.260	662.198	680.593
65	394.330	427.670	493.200	534.587	548.383
70	265.569	306.957	372.487	415.024	431.119
75	167.849	208.087	267.868	310.405	331.099
80	90.822	125.312	178.196	208.087	228.780
85	32.190	56.333	73.578	73.578	91.972
90	0.000	0.000	0.000	0.000	0.000

IES INDOOR REPORT
PHOTOMETRIC FILENAME : PTDC-22-L43-840-RA-DIM-UNV_.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	624.60	N.A.	14.00
0-30	1319.86	N.A.	29.50
0-40	2139.68	N.A.	47.80
0-60	3634.99	N.A.	81.30
0-80	4391.23	N.A.	98.20
0-90	4473.06	N.A.	100.00
10-90	4311.26	N.A.	96.40
20-40	1515.08	N.A.	33.90
20-50	2328.00	N.A.	52.00
40-70	1975.39	N.A.	44.20
60-80	756.24	N.A.	16.90
70-80	276.17	N.A.	6.20
80-90	81.83	N.A.	1.80
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	4473.06	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	161.81
10-20	462.79
20-30	695.26
30-40	819.81
40-50	812.92
50-60	682.39
60-70	480.07
70-80	276.17
80-90	81.83
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : PTDC-22-L43-840-RA-DIM-UNV_.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	97	106	102	98	95	98	95	92	94	91	89	90	88	86	84
2	100	91	85	79	97	90	83	78	86	81	76	83	79	75	80	76	73	71
3	91	81	73	66	89	79	72	66	76	70	65	73	68	63	71	66	62	60
4	83	72	63	57	81	70	62	56	68	61	55	66	60	55	63	58	54	52
5	77	64	55	49	75	63	55	49	61	54	48	59	53	48	57	52	47	45
6	71	58	49	43	69	57	49	43	55	48	42	54	47	42	52	46	42	40
7	66	53	44	38	64	52	44	38	50	43	38	49	42	37	48	42	37	35
8	62	48	40	34	60	47	39	34	46	39	34	45	38	33	44	38	33	31
9	58	44	36	31	56	44	36	31	43	35	30	41	35	30	40	34	30	28
10	54	41	33	28	53	40	33	28	39	32	28	38	32	28	38	32	27	26

IES INDOOR REPORT
PHOTOMETRIC FILENAME : PTDC-22-L43-840-RA-DIM-UNV_.IES

UGR TABLE - CORRECTED


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	16.0	17.6	16.3	17.9	18.2	17.0	18.6	17.4	18.9	19.2
	3H	17.3	18.7	17.6	19.0	19.4	18.8	20.3	19.2	20.6	21.0
	4H	17.7	19.0	18.1	19.4	19.8	19.6	21.0	20.0	21.3	21.7
	6H	17.9	19.2	18.4	19.6	20.0	20.3	21.6	20.7	21.9	22.3
	8H	18.0	19.2	18.4	19.6	20.0	20.5	21.7	21.0	22.1	22.5
	12H	18.0	19.2	18.5	19.6	20.0	20.7	21.8	21.1	22.2	22.7
4H	2H	16.7	18.0	17.1	18.4	18.8	17.5	18.9	17.9	19.2	19.6
	3H	18.2	19.3	18.6	19.7	20.1	19.6	20.7	20.0	21.1	21.5
	4H	18.8	19.8	19.2	20.2	20.6	20.5	21.5	20.9	21.9	22.4
	6H	19.1	20.0	19.6	20.5	20.9	21.4	22.3	21.8	22.7	23.2
	8H	19.2	20.1	19.7	20.5	21.0	21.7	22.5	22.1	22.9	23.4
	12H	19.3	20.1	19.8	20.5	21.0	21.9	22.6	22.3	23.1	23.6
8H	4H	19.2	20.0	19.7	20.5	21.0	20.8	21.6	21.2	22.0	22.5
	6H	19.7	20.4	20.2	20.9	21.4	21.7	22.4	22.2	22.9	23.4
	8H	19.9	20.5	20.4	21.1	21.5	22.1	22.8	22.7	23.3	23.8
	12H	20.0	20.6	20.5	21.1	21.6	22.4	23.0	22.9	23.4	24.0
12H	4H	19.3	20.0	19.8	20.5	21.0	20.8	21.5	21.2	22.0	22.5
	6H	19.9	20.5	20.4	21.0	21.5	21.8	22.4	22.3	22.9	23.4
	8H	20.1	20.7	20.6	21.2	21.7	22.2	22.8	22.7	23.3	23.8

Maximum UGR = 24.0

POLAR GRAPH



Maximum Candela = 1715.278 Located At Horizontal Angle = 0, Vertical Angle = 5

1 - Vertical Plane Through Horizontal Angles (90 - 270)

2 - Horizontal Cone Through Vertical Angle (5) (Through Max. Cd.)