



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : PTS-14-L25-8FS-SA.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002  
 [TEST]GEN from BALLABS TEST NO. 20790.0  
 [TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC  
 [ISSUE DATE] 03-MAY-2019  
 [MANUFAC] WILLIAMS INDOOR  
 [OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO  
 [LUMINAIRE] 2-84 LED 22"ARRAYS w/WHITE REFLECTOR  
 [MORE] FROST SQUARED RIBBED LENS - 1x4 SURFACE LUMINAIRE  
 [MORE] ADVANCE #XI075C200V054BST1 @ 1525mA  
 [LUMCAT] PTS-14-L25-8FS-SA-DIM-UNV

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	2514
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	127
Total Luminaire Watts	19.8
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.16
Spacing Criterion (Diagonal)	1.28
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.92 ft
Luminous Width (90-270)	0.98 ft
Luminous Height	0.00 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	2246	2177	2161
55	2021	2033	2078
65	1766	1955	2141
75	1426	1973	2462
85	661	2130	2574

IES INDOOR REPORT  
PHOTOMETRIC FILENAME : PTS-14-L25-8FS-SA.IES

CANDELA TABULATION

	<u>0.0</u>	<u>22.5</u>	<u>45.0</u>	<u>67.5</u>	<u>90.0</u>
<b>0</b>	979.063	979.063	979.063	979.063	979.063
<b>5</b>	983.927	973.118	967.713	954.201	966.632
<b>10</b>	965.011	953.390	946.364	945.013	946.905
<b>15</b>	933.123	921.773	915.557	913.396	911.774
<b>20</b>	890.696	879.616	869.347	864.213	865.023
<b>25</b>	837.730	828.542	824.218	810.706	805.572
<b>30</b>	775.846	766.388	756.659	749.363	745.309
<b>35</b>	711.530	702.882	691.262	681.263	675.588
<b>40</b>	637.756	630.729	618.569	610.732	606.138
<b>45</b>	566.413	558.306	548.848	544.524	544.795
<b>50</b>	491.018	488.586	478.317	480.208	482.640
<b>55</b>	413.460	413.460	415.892	422.378	425.080
<b>60</b>	341.307	342.929	354.008	365.088	371.844
<b>65</b>	266.182	275.910	294.557	313.743	322.661
<b>70</b>	194.029	210.243	236.996	262.669	273.208
<b>75</b>	131.605	148.359	182.139	215.378	227.268
<b>80</b>	68.910	97.555	132.686	167.816	178.896
<b>85</b>	20.538	46.210	66.208	75.125	79.990
<b>90</b>	0.000	0.811	1.081	1.892	1.081

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : PTS-14-L25-8FS-SA.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	350.32	N.A.	13.90
0-30	727.88	N.A.	29.00
0-40	1160.5	N.A.	46.20
0-60	1961.26	N.A.	78.00
0-80	2445.93	N.A.	97.30
0-90	2514.11	N.A.	100.00
10-90	2422.24	N.A.	96.30
20-40	810.18	N.A.	32.20
20-50	1236.44	N.A.	49.20
40-70	1092.94	N.A.	43.50
60-80	484.67	N.A.	19.30
70-80	192.49	N.A.	7.70
80-90	68.19	N.A.	2.70
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	2514.11	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	91.88
10-20	258.44
20-30	377.56
30-40	432.61
40-50	426.26
50-60	374.50
60-70	292.18
70-80	192.49
80-90	68.19
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00


**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : PTS-14-L25-8FS-SA.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	104	99	95	106	101	97	94	97	94	91	93	90	88	89	87	85	83
2	99	90	83	77	96	88	82	77	85	79	75	81	77	73	78	75	71	69
3	90	79	71	65	87	78	70	64	75	68	63	72	66	62	69	65	61	58
4	83	70	62	55	80	69	61	55	67	59	54	64	58	53	62	57	52	50
5	76	63	54	47	74	62	54	47	60	52	47	58	51	46	56	50	46	44
6	70	57	48	42	68	56	48	41	54	47	41	53	46	41	51	45	40	38
7	65	52	43	37	64	51	43	37	49	42	37	48	41	36	47	41	36	34
8	61	47	39	33	59	47	39	33	45	38	33	44	37	33	43	37	32	30
9	57	44	35	30	56	43	35	30	42	35	30	41	34	29	40	34	29	27
10	53	40	32	27	52	40	32	27	39	32	27	38	31	27	37	31	27	25

POLAR GRAPH



Maximum Candela = 983.927 Located At Horizontal Angle = 0, Vertical Angle = 5  
# 1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (5) (Through Max. Cd.)