



UL Verification Services Inc.  
7036 Snowdrift Road  
Allentown, PA 18106  
610-774-1300



## Electrical Test Report

Relavant Standards  
ANSI C82.77-2002

Prepared For  
H E Williams Inc  
831 W Fairview Ave  
PO Box 837  
Carthage, MO 64836-0837  
United States

Catalog Number  
SRKA-X4-L31/830-X-XXX-UNV (Driver 5)

Test Number  
12118431.01

Test Date

Prepared By

Javier Caban, Technician

Approved By

Jeffrey Lockner, Project Engineer

The results contained in this report pertain only to the tested sample.

This report shall not be reproduced, except in full, without written approval of Underwriters Laboratories.

This report must not be used by the client to claim product certification, approval, or endorsement by  
NVLAP, NIST, or any agency of the Federal Government.




UL Verification Services Inc.  
7036 Snowdrift Road  
Allentown, PA 18106  
610-774-1300



Luminaire Description: White formed steel housing, clear plastic optic. Tested in Columbia CS Bi-Pin  
2L reference housing.  
Catalog Number: SRKA-X4-L31/830-X-XXX-UNV (Driver 5)  
Lamp: 56 white LEDs  
Mounting: Surface – Ceiling  
Ballast/Driver: One Philips XI020C056V054BST2 driver

Luminaire



#### Test Conditions

Test Temperature: 25.2 °C

#### Input Electrical Values

Voltage:	120 VAC	277 VAC
Current:	0.1867 A	0.08216 A
Power:	22.33 W	22.11 W
Power Factor:	0.997	0.972
Frequency:	60 Hz	60 Hz
Voltage THD:	0.05%	0.05%
Current THD:	6.73%	10.91%